



250008343110



中国认可
国际互认
检测
TESTING
CNAS L0681



CHPTL

TEST REPORT

No : CTQC/ZJ-25. 1399

Test object name: Self-diagnostic resin-impregnated fiber capacitive transformer bushing

Test object type: QXZBRGW-126/2500-4

Entrusted by: Shandong Qixing High Voltage Electric Co., Ltd.

Manufacturer: Shandong Qixing High Voltage Electric Co., Ltd.

Kind of testing: Type tests



SHENYANG TRANSFORMER RESEARCH INSTITUTE CO., LTD.

CHINA NATIONAL TRANSFORMER QUALITY INSPECTION AND TESTING CENTER

CX-F-01	Test Report	No: CTQC/ZJ-25.1399 Total 21 Page 1
---------	-------------	--

CONTENTS

	Page
1. Test report cover	
2. Contents.....	1
3. Signing and issuing.....	2
4. Test results.....	3~5
5. Test object parameters.....	6
6. Sample condition description.....	6
7. Standards	6
8. Test items and conclusions.....	7~21
9. Annex 1: Rating plate and outline photos(Total page 1)	
10. Annex 2: Bushing drawings(Total pages 2)	

Shenyang Transformer Research Institute Co., Ltd.

China National Transformer Quality Inspection And Testing Center

Test Report

No: CTQC/ZJ-25.1399

Total 21 Page 2

Test object name	Self-diagnostic resin-impregnated fiber capacitive transformer bushing	Test object type	QXZBRGW-126/2500-4
		Brand	/
Entrusted by	Shandong Qixing High Voltage Electric Co., Ltd.	Kind of testing	Type test
Manufacturer	Shandong Qixing High Voltage Electric Co., Ltd.	Sampling date	/
		Test date	July 17, 2025~July 19, 2025
Address	No.1228, Pengcheng Industrial Park, Pingli Road, Xiazhuang Town, Gaomi City, Weifang City, Shandong Province	Serial No	2507CBT002S
Standards	IEC60137 Edition 7.0 2017-06 GB/T4109-2022 Technical contract	Test items	Routine tests Type tests
Results	The test results of routine tests, type tests of QXZBRGW-126/2500-4 are in accordance with standards and technical contract. The sample passed the above tests.		
Note	 Signing and issuing date: <i>2025.07.23</i> 		

Approved by: Lv Xiangpeng

Checked by: Zhang Guofeng

Compiled by: Jiang Anping

- Statement
1. Testing report is invalid without test special seal.
 2. Testing report is invalid without compiler, checker and approver's signature.
 3. Please inform CTQC in time after received the testing report if you have some disagreement to the testing report.
 4. Testing or witnessing only apply to sample.
 5. Copying testing certificate or testing report is forbidden without written permission from CTQC (except for copying all the testing report).

Test Report

No: CTQC/ZJ-25.1399

Total 21 Page 3

Test results

№	Test items	Specified values	Measured values	Conclusions
		Standards(Technical contract)		
1	Measurement of dielectric dissipation factor($\tan\delta$) and capacitances at ambient temperature (Before type test)	Applied voltage(kV): 2~20 $\tan\delta: \leq 0.004$ Providing capacitance of the sample(pF)	10 0.00264 405.4	Passed
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ $\tan\delta: \leq 0.004$ Providing capacitance of the sample(pF)	76.4 0.00268 405.7	
		Applied voltage(kV): U_m $\tan\delta: \leq 0.004$ Providing capacitance of the sample(pF)	126 0.00269 405.8	
2	Measurement of partial discharge quantity (Before type test)	Applied voltage(kV): U_m Partial discharge level(pC): ≤ 10	126 <5	Passed
		Applied voltage(kV): $1.5U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 10	109.1 <4	
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 5	76.4 <4	
3	Dry lightning impulse voltage withstand test (Type test)	Full wave voltage Positive polarity(kV): 909.2(Corrected value) $\pm 3\%$ Negative polarity(kV): 1000.2(Corrected value) $\pm 3\%$ 15 positive and 15 negative polarity Chopped wave voltage(kV): 1100.2(Corrected value) $\pm 3\%$ 5 negative polarity	895.63~903.00 987.59~1013.86 Each 15 times 1094.32~1101.49 5 times	Passed
4	Wet power-frequency voltage withstand test (Type test)	Applied voltage(kV): 374.2(Corrected value) Duration(s): 60	374.2 60	Passed
5	Long-duration power-frequency voltage withstand test(ACLD) (Type test)	$U_1=U_m$ (kV) Duration(s): 60	126 60	Passed
		$U_2=1.5U_m/\sqrt{3}$ (kV) Duration(min): 60 Partial discharge level(pC): ≤ 10	109.1 60 <5	
		$1.1U_m/\sqrt{3}$ (kV) Duration(min): 5 Partial discharge level(pC): ≤ 5	80 5 <5	
6	Radio interference voltage test (Type test)	Applied voltage(kV): $1.1U_m/\sqrt{3}$ Duration(min): 5 Radio interference level(μ V): ≤ 500	80 5 223	Passed
7	Temperature rise test (Type test)	Temperature limit($^{\circ}$ C): 105/120 Temperature rise limit(K): 75/90	See 4.7	Passed

Test Report			№: CTQC/ZJ-25. 1399 Total 21 Page 4	
№	Test items	Specified values	Measured values	Conclusions
		Standards(Technical contract)		
8	Verification of thermal short-time current withstand (Type test)	Thermal short-time current(kA): $25I_r$ Duration(s): 2 Final temperature (°C): ≤ 180	62.5 2 157.6	Passed
9	Cantilever load withstand test (Type test)	Applied load(N): 5000 Duration(s): 60 Successfully repeat check items	5098 60 Passed	Passed
10	Visual inspection and dimensions check (Type test)	According to standard	See 4.10	Passed
11	Measurement of partial discharge quantity (After type test)	Applied voltage(kV): U_m Partial discharge level(pC): ≤ 10	126 <4	Passed
		Applied voltage(kV): $1.5U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 10	109.1 <4	
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 5	76.4 <4	
12	Measurement of dielectric dissipation factor($\tan\delta$) and capacitances at ambient temperature (After type test)	Applied voltage(kV): 2~20 $\tan\delta$: ≤ 0.004 Providing capacitance of the sample(pF)	10 0.00294 401.6	Passed
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ $\tan\delta$: ≤ 0.004 Providing capacitance of the sample(pF)	76.4 0.00295 401.9	
		Applied voltage(kV): U_m $\tan\delta$: ≤ 0.004 Providing capacitance of the sample(pF)	126 0.00295 401.9	
13	Test of tap insulation (Routine test)	Dry power-frequency voltage withstand test: Applied voltage(kV): 2~3 Duration(s): 60	2 60	Passed
		Measurement of dielectric dissipation factor($\tan\delta$) and capacitances Applied voltage(kV): ≥ 1 $\tan\delta$: ≤ 0.05 Capacitance(pF): ≤ 10000	2 0.00651 349.4	
14	Dry lightning impulse voltage withstand test (Routine test)	Negative polarity(kV): 577.5 $\pm 3\%$ 3 negative polarity Chopped wave voltage(kV): 632.5 $\pm 3\%$ 2 negative polarity	560.33~577.58 3 times 629.32~631.94 2 times	Passed
15	Dry power-frequency voltage withstand test (Routine test)	Applied voltage(kV): 255 Duration(s):60	255 60	Passed

Test Report			№: CTQC/ZJ-25.1399 Total 21 Page 5	
№	Test items	Specified values	Measured values	Conclusions
		Standards(Technical contract)		
16	Measurement of partial discharge quantity (Routine test)	Applied voltage(kV): U_m Partial discharge level(pC): ≤ 10	126 <4	Passed
		Applied voltage(kV): $1.5U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 10	109.1 <4	
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 5	76.4 <4	
17	Measurement of dielectric dissipation factor($\tan\delta$) and capacitances at ambient temperature (Routine test)	Applied voltage(kV): 2~20 $\tan\delta$: ≤ 0.004 Providing capacitance of the sample(pF)	10 0.00296 401.5	Passed
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ $\tan\delta$: ≤ 0.004 Providing capacitance of the sample(pF)	76.4 0.00298 401.8	
		Applied voltage(kV): U_m $\tan\delta$: ≤ 0.004 Providing capacitance of the sample(pF)	126 0.00298 401.8	
18	Tightness test at the flange or other fixing device (Routine test)	Applied medium Applied pressure(MPa): 0.8 ± 0.01 Duration(min): 15 No oil leakage and damage	SF ₆ 0.8 15 No oil leakage and damage	Passed
19	Visual inspection and dimensions check (Routine test)	According to standard	See 4.19	Passed

Note: 1. All the tests were field tests;
2. Tested in Shandong Qixing High Voltage Electric Co., Ltd. testing station;
3. Enterprise requirements: Did not perform altitude correction in this test, and the relevant test datas were provided by entrusting company.

Test Report		No: CTQC/ZJ-25.1399 Total 21 Page 6
<p>1. Test object parameters</p> <p>Highest voltage for equipment(kV): 126</p> <p>Rated phase-to-earth voltage(kV): $126/\sqrt{3}$</p> <p>Rated current(A): 2500</p> <p>Rated frequency(Hz): 50</p> <p>Altitude(m): ≤ 5000</p> <p>Temperature class of insulation: E</p> <p>Test tap(measured tap, $\tan\delta$): With</p> <p>Insulation type of bushing: RIF</p> <p>Rated voltage of tap(Tap of electric potential, tap of capacitance)(kV): /</p> <p>2. Sample condition description</p> <p>Sample exterior construction and major dimensions(length, outer diameter) are in compliance with outline drawings.</p> <p>Measured values: length is 3412 mm, outer diameter is $\Phi 400$ mm.</p>		
Outline dimensions	Rating plate	
ZCBT6006GY	8QX.860.009G	
<p>Rating plate and outline drawings are in testing report annex.</p> <p>The design, performance data, specifications of sample rating plate are in compliance with drawing.</p> <p>The marking of the phase sequence on head terminal and end terminal of the sample is clear and right.</p> <p>The surface of the sample has no collision and damage.</p> <p>3. Standards</p> <p>IEC60137 Edition 7.0 2017-06 Insulated bushings for alternating voltages above 1000V</p> <p>GB/T4109-2022 Insulated bushings for alternating voltages above 1000V</p> <p>Technical contract</p>		

Test Report			No: CTQC/ZJ-25. 1399 Total 21 Page 7	
4. Test items and conclusions				
4.1 Measurement of dielectric dissipation factor ($\tan \delta$) and capacitances at ambient temperature (Before type test) Test date: July 17, 2025				
Humidity: 51.0%; Ambient temperature: 31.6°C; Atmospheric pressure: 100.5kPa				
Applied voltage(kV)	Dielectric dissipation factor($\tan \delta$)	Capacitance(pF)	Result	
10	0.00264	405.4	Passed	
76.4	0.00268	405.7		
126	0.00269	405.8		
Note: $\tan \delta(126kV) - \tan \delta(76.4kV) = 0.00001 < 0.001$ (Standard value), passed.				
4.2 Measurement of partial discharge quantity (Before type test) Test date: July 17, 2025				
Humidity: 51.0%; Ambient temperature: 31.6°C; Atmospheric pressure: 100.5kPa				
Prestress voltage (kV)	Duration(s)	Measured voltage (kV)	Partial discharge level(pC)	Result
255	60	126	<5	Passed
		109.1	<4	
		76.4	<4	
Note: Background level was <4pC before and after test.				
4.3 Dry lightning impulse voltage withstand test (Type test) Test date: July 17, 2025				
Test atmospheric conditions: Humidity: 51.0%; Ambient temperature: 31.6°C; Atmospheric pressure: 100.5kPa.				
Full wave rated withstand voltage: Positive polarity(kV): 909.2(Corrected value) Negative polarity(kV): 100.2(Corrected value) 15 negative and 15 positive polarity impulses; Chopped wave rated withstand voltage(kV): 1100.2(Corrected value) 5 negative polarity impulses.				
Test sequence: One positive polarity reference voltage full wave impulse; Fifteen positive polarity rated voltage full wave impulse; One negative polarity reference voltage full wave impulse; One negative polarity rated voltage full wave impulse; Five negative polarity rated chopped wave impulse; Fourteen negative polarity rated voltage full wave impulse.				
Test oscillogram records: T1: Front time; T2: Time to half value; Upk: Peak voltage; Tc: Time to chopping; Qz: Factor of over crossing Result: Passed.				

Test Report









No: CTQC/ZJ-25.1399

Total 21 Page 8

Tested terminal: To earth

Test polarity: Positive

CH2: Voltage records



Test Report









No: CTQC/ZJ-25.1399

Total 21 Page 9

Tested terminal: To earth

Test polarity: Positive

CH2: Voltage records



Test Report








No: CTQC/ZJ-25.1399

Total 21 Page 10

Tested terminal: To earth

Test polarity: Negative

CH2: Voltage records



Test Report









No: CTQC/ZJ-25.1399

Total 21 Page 11

Tested terminal: To earth

Test polarity: Negative

CH2: Voltage records



Test Report







No: CTQC/ZJ-25.1399

Total 21 Page 12

Tested terminal: To earth

Test polarity: Negative

CH2: Voltage records



Test Report					No: CTQC/ZJ-25.1399 Total 21 Page 13		
4.4 Wet power-frequency voltage withstand test (Type test)					Test date: July 17, 2025		
Humidity: 51.0%; Ambient temperature: 31.6°C; Atmospheric pressure: 100.5kPa							
Applied position	Applied voltage(kV)				Frequency (Hz)	Duration (s)	Result
	Standard value	Atmospheric corrected value	Altitude corrected value	Applied value			
Terminal-earth	230	374.9	374.2	374.2	50	60	Passed
<p>Note: The conductivity of collected water is 101.5μS/cm at 20°C. Average precipitation rate: Vertical component 1.7mm/min, horizontal component 1.4mm/min.</p>							
4.5 Long-duration power-frequency withstand voltage test (ACLD) (Type test)					Test date: July 18, 2025		
Humidity: 48.0%; Ambient temperature: 32.5°C; Atmospheric pressure: 100.6kPa							
Applied voltage		Duration(min)	Partial discharge level(pC)				
Multiple	Phase-earth(kV)						
$1.1U_m/\sqrt{3}$	80	5	<5				
$U_2=1.5U_m/\sqrt{3}$	109.1	5	<5				
$U_1=U_m$	126	1	/				
$U_2=1.5U_m/\sqrt{3}$	109.1	5	<5				
		10	<5				
		15	<5				
		20	<5				
		25	<5				
		30	<5				
		35	<5				
		40	<5				
		45	<5				
		50	<5				
		55	<5				
		60	<5				
$1.1U_m/\sqrt{3}$	80	5	<5				
<p>Note: $U_m=126$kV; Background level was <5pC before and after test. Result: Passed.</p>							

<h2 style="margin: 0;">Test Report</h2>	No: CTQC/ZJ-25.1399 Total 21 Page 14
---	---

4.6 Radio interference voltage test (Type test)


Test date: July 18, 2025

Humidity: 48.0%; Ambient temperature: 32.5°C; Atmospheric pressure: 100.6kPa

Measured frequency (MHz)	Attenuation factor of measurement circuit (dB)	Attenuation factor of resistance network (dB)	Measured voltage (kV)	Duration (min)	Radio interference reading B_m (dB)	Radio interference level (μV)
1.0	7	22	80	5	18	223
			72.7	/	18	223
			65.5		18	223
			58.2		17	200
			50.9		17	200
			43.6		17	200
			36.4		16	178
			29.1		16	178
			21.8		16	178

Result: Passed.

Radio interference curve



Test Report

No: CTQC/ZJ-25.1399

Total 21 Page 15

4.7 Temperature-rise test (Type test)

Test date: July 17, 2025

Specified current was 2500A, injected current was 2500A during test, the test duration was 7h, stability duration was 1h.

Calculated result of temperature rise

No.	Measured position	Temperature of bushing (°C)	Temperature rise of bushing(K)	Oil temperature (°C)	Ambient temperature (°C)	Result
1	Terminal in the air	75.6	46.2	29.6	90.8	Passed
2	Fastening of terminals in the air	74.4	44.8			
3	Flange	49.6	20.0			
4	Terminal in the oil	93.0	63.4			


Note: The measurement position drawing is shown in page 16.

Test Report

No: CTQC/ZJ-25.1399

Total 21 Page 16

Schematic diagram of measured point of temperature rise



- 1. Terminal in the air
- 2. Fastening of terminals in the air
- 3. Flange
- 4. Terminal in the oil

Test Report

No: CTQC/ZJ-25.1399

Total 21 Page 17

4.8 Verification of thermal short-time current withstand (Verify by the calculation)

(Type test)

Test date: July 19, 2025

The standard value of thermal short-time current of bushing $I_{th}=62.5\text{kA}$, duration $t_{th}=2\text{s}$. According to calculation final temperature of the conductor $\theta_f=157.6^\circ\text{C}$. If $\theta_f \leq 180^\circ\text{C}$, it was considered that the bushing could withstand the standard value I_{th} of thermal short-time current.

Sample parameters

Conductor material of sample	Aluminum
Conductor resistivity $\rho(\mu\Omega \cdot \text{cm})$	2.83
Total cross section area $S_t(\text{cm}^2)$	28.26
Measured temperature rise of the bushing(K)	90
Rated current $I_r(\text{A})$	2500
Standard value of rated thermal short-time current $I_{th}(\text{kA})$	62.5
Rated duration $t_{th}(\text{s})$	2
$\theta_0(^\circ\text{C})$	130
Current penetration depth $d(\text{cm})$	1.197
Diameter of the conductor $D(\text{cm})$	6.0
$\alpha[(\text{K/s})/(\text{kA}/\text{cm}^2)^2]$	1.8
Equivalent cross section area considering the skin effect $S_e(\text{cm}^2)$	18.06

Verify by the calculation:

$$\theta_f = \theta_0 + \alpha \frac{I_{th}^2}{S_t \times S_e} \times t_{th} = 157.6^\circ\text{C}$$

Result: Passed.

Test Report					No: CTQC/ZJ-25.1399 Total 21 Page 18	
4.9 Cantilever load withstand test (Type test)					Test date: July 19, 2025	
Load direction	Applied position	Standard value		Applied value		Result
		Load(N)	Duration(s)	Load(N)	Duration(s)	
Vertical	Terminal	5000	60	5098	60	No damage, distortion, passed
4.10 Visual inspection and dimensions check (Type test)					Test date: July 19, 2025	
It has smooth surface, no cracks. Dimensional check is accordance with the drawing requirement.						
Drawing values(mm): 3410±20 1170±10 1620±10 Φ400 120						
Measured values(mm): 3412 1172 1610 Φ400 120						
Arcing distance(mm): 1630 Creepage(mm): 5725						
Result: Passed.						
4.11 Measurement of partial discharge quantity (After type test)					Test date: July 19, 2025	
Humidity: 50.0%; Ambient temperature: 33.1°C; Atmospheric pressure: 100.8kPa						
Prestress voltage (kV)	Duration(s)	Measured voltage(kV)	Partial discharge level(pC)	Result		
255	60	126	<4	Passed		
		109.1	<4			
		76.4	<4			
Note: Background level was <4pC before and after test.						
4.12 Measurement of dielectric dissipation factor (tan δ) and capacitances at ambient temperature (After type test)					Test date: July 19, 2025	
Humidity: 50.0%; Ambient temperature: 33.1°C; Atmospheric pressure: 100.8kPa						
Applied voltage(kV)	Dielectric dissipation factor (tanδ)	Capacitance(pF)	Result			
10	0.00294	401.6	Passed			
76.4	0.00295	401.9				
126	0.00295	401.9				
Note: tanδ(126kV)- tanδ(76.4kV) = 0.00000 < 0.001 (Standard value), passed.						







Test Report				No: CTQC/ZJ-25.1399 Total 21 Page 19	
4.13 Tests of tap insulation(Routine test)				Test date: July 19, 2025	
Power-frequency voltage withstand test					
Humidity: 50.0%; Ambient temperature: 33.1°C; Atmospheric pressure: 100.8kPa					
Applied position	Applied voltage(kV)	Frequency(Hz)	Duration(s)	Result	
Tap-earth	2	50	60	Passed	
Measurement of dielectric dissipation factor(tanδ) and capacitances					
Humidity: 50.0%; Ambient temperature: 33.1°C; Atmospheric pressure: 100.8kPa					
Applied voltage(kV)	Dielectric dissipation factor(tanδ)	Capacitance(pF)	Result		
2	0.00651	349.4	Passed		
4.14 Dry lightning impulse voltage withstand test(Routine test)				Test date: July 19, 2025	
Test atmospheric conditions					
Humidity: 50.0%; Ambient temperature: 33.1°C; Atmospheric pressure: 100.8kPa					
Full wave rated withstand voltage: negative polarity(kV): 577.5;				3 negative polarity	
Chopped wave rated withstand voltage: negative polarity(kV): 632.5;				2 negative polarity	
Test sequence					
One negative reference full wave impulse;					
One negative rated full wave impulses;					
Two negative rated chopped wave impulses;					
Two negative rated full wave impulses.					
Test records:					
T1: Front time;		T2: Time to half value;		Upk: Peak voltage;	
Tc: Time to chopping;		Qz: Factor of over crossing.			
Result: Passed.					

Test Report

No: CTQC/ZJ-25. 1399

Total 21 Page 20

Tested terminal: To earth Test polarity: Negative CH2: Voltage wave



Test Report				No: CTQC/ZJ-25.1399 Total 21 Page 21	
4.15 Dry power-frequency voltage withstand test(Routine test)				Test date: July 19, 2025	
Humidity: 50.0%; Ambient temperature: 33.1°C; Atmospheric pressure: 100.8kPa					
Applied position	Applied voltage(kV)		Frequency (Hz)	Duration (s)	Result
	Standard value	Applied value			
Terminal-earth	255	255	50	60	Passed
4.16 Measurement of partial discharge quantity(Routine test)				Test date: July 19, 2025	
Humidity: 50.0%; Ambient temperature: 33.1°C; Atmospheric pressure: 100.8kPa					
Prestress voltage (kV)	Duration(s)	Measured voltage(kV)	Partial discharge level(pC)	Result	
255	60	126	<4	Passed	
		109.1	<4		
		76.4	<4		
Note: Background level was <4pC before and after test.					
4.17 Measurement of dielectric dissipation factor($\tan \delta$) and capacitances at ambient temperature(Routine test)				Test date: July 19, 2025	
Humidity: 50.0%; Ambient temperature: 33.1°C; Atmospheric pressure: 100.8kPa					
Applied voltage(kV)	Dielectric dissipation factor($\tan \delta$)	Capacitance(pF)	Result		
10	0.00296	401.5	Passed		
76.4	0.00298	401.8			
126	0.00298	401.8			
Note: $\tan \delta(126\text{kV}) - \tan \delta(76.4\text{kV}) = 0.00000 < 0.001$ (Standard value), Passed.					
4.18 Tightness test at the flange or other fixing device(Routine test)				Test date: July 19, 2025	
Ambient temperature: 33.1°C					
Applied medium	Applied pressure(MPa)	Duration(h)	Residual pressure(MPa)	Result	
SF ₆	0.8	15	0.8	No leakage or damage, passed	
4.19 Visual inspection and dimensions check(Routine test)				Test date: July 19, 2025	
It has smooth surface, no cracks. Dimensional check is accordance with the drawing requirement.					
Dimensional inspection see 4.10.					
Result: Passed.					

RATING PLATE AND OUTLINE PHOTOS


Rating plate:



Outline:




BUSHING DRAWINGS



B - B to the sketch




Schematic diagram in direction a



Technical parameters

1. Rated voltage: 126kV
2. Rated current :2500A
3. Min power frequency withstand voltage: 255kV
4. Lightning impulse withstand voltage: 550kV
5. Dielectric loss tangent: ≤ 0.4%
6. PD: Um measured ≤ 10
7. Bending load: 5000N
8. Creepage distance: 5720mm
9. weight:300kg
10. Altitude:5000m

Shandong Xiang High Voltage Electric Co., Ltd.		Dry-type transformer bushing outline	
QXZBRGW-126/2500-4		阶段标记	重量
标记	处数	分区	更改文件号
设计	张艺潇	2025.7.8	标准化
审核	石孝刚	2025.7.8	
工艺			
批准	曹明波	2025.7.8	
共	张	第	张
Product number:			ZCBT6006GY



借 (通) 用
件 登 记

旧底图总号						产品型号		装配图代号	序号
底图总号						铭牌nameplate		80X.860.009G	
签字							图样标记	重量	比例
日期	标记	处数	分区	更改文件号	签字		日期		0.030
档案员	日期	设计	张艺瀚	2025.7.1	标准化			共 张	第 张
		校核	石孝刚	2025.7.1	审定			Shandong Qixing High Voltage Electric Co. Ltd. 山东七星高压电气有限公司	
		会签			批准	曹明波	2025.2.1		



CHPTL

中国大容量试验联盟(简称 CHPTL)是中国同类试验机构的唯一协作组织,隶属于中国电工技术学会。其主要目标是规范国家标准、行业标准及 IEC 标准在电力设备(交流 1000V 以上,直流 1200V 以上)Type test 试验中的协调应用。

China High Power Testing liaison (CHPTL) is the only organization in China which is formed to promote and coordinate the application of IEC/GB standard as well as industry standards in power electrical equipment type test (AC above 1000V, DC above 1200V). CHPTL is under the leadership and management of China Electro-technical Society.

CHPTL 成员单位如下:

The members of CHPTL are as follows:

西安高压电器研究院有限责任公司(XIHARI)

Xi'an High Voltage Apparatus Research Institute Co., Ltd. (XIHARI)

中国电力科学研究院(CEPRI)

China Electrical Power Research Institute (CEPRI)

辽宁高压电器产品质量检测有限公司(AQTC)

Liaoning High Voltage Apparatus Quality Test Co., Ltd. (AQTC)

沈阳变压器研究院有限公司变压器实验室(STRI)

Shenyang Transformer Institute Co., Ltd Transformer Laboratory (STRI)

上海电气输配电试验中心有限公司(SETC)

Shanghai Electric Power Transmission & Distribution Testing Center Co., Ltd. (SETC)

电力工业无功补偿成套装置质量检验测试中心(PRCIQTC)

Power Industry Reactive Compensation Equipment Quality Inspection & Test Center(PRCIQTC)

CHPTL 作为一个协作组织,本身并不出具 Type test 试验报告。每一个 CHPTL 成员对其出具的 Type test 试验报告的有效性和内容负责。

CHPTL as a collaboration does not itself issue test reports. Each CHPTL member issuing a test report is responsible for the validity and contents of