



230008349512



中国认可  
国际互认  
检测  
TESTING  
CNAS L0681



**CHPTL**

# TEST REPORT

No : CTQC/ZJ-23. 0045

Test object name: Adhesive paper capacitive transformer  
bushing

Test object type: QXBRP(G)WD-L-126/1600-4

Entrusted by: Shandong Qixing High Voltage Electric  
CO., Ltd.

Manufacturer: Shandong Qixing High Voltage Electric  
CO., Ltd.

Kind of testing: Type tests



SHENYANG TRANSFORMER RESEARCH INSTITUTE CO., LTD.

CHINA NATIONAL TRANSFORMER QUALITY DETECTION AND TESTING CENTER

CX-F-01	Test Report	No: CTQC/ZJ-23.0045 Total 22 Page 1
---------	-------------	--

## CONTENTS

	Page
1. Test report cover	
2. Contents.....	1
3. Signing and issuing.....	2
4. Test results.....	3~5
5. Test object parameters.....	6
6. Sample condition description.....	6
7. Standards .....	6
8. Test items and conclusions.....	7~22
9. Annex 1: Rating plate and outline photo(Total page 1)	
10. Annex 2: Bushing drawings(Total pages 2)	

Shenyang Transformer Research Institute Co., Ltd.

China National Transformer Quality Detection And Testing Center

## Test Report

No: CTQC/ZJ-23.0045

Total 22 Page 2


Test object name	Adhesive paper capacitive transformer bushing	Test object type	QXBRP(G)WD-L-126/1600-4
		Brand	/
Entrusted by	Shandong Qixing High Voltage Electric Co., Ltd.	Kind of testing	Type tests
Manufacturer	Shandong Qixing High Voltage Electric Co., Ltd.	Sampling date	/
		Test date	Feb. 17, 2023~Feb. 23, 2023
Address	No. 1228, Pengcheng Industrial Park, Pingli Road, Xiazhuang Town, Gaomi City, Weifang City, Shandong Province	Serial No	2302PB001
Standards	IEC60137: 2017 GB/T4109-2022 Technical contract	Test items	Routine tests Type tests
Results	The test results of routine tests, type tests of QXBRP(G)WD-L-126/1600-4 are in accordance with standards and technical contract. The sample passed the above tests.		
	Signing and issuing date: 2023.03.09		
Note			

Approved by: Lv Xiangpeng

Checked by: Zhou Jingwei

Compiled by: Jiang Anping





Statement: 1. Testing report is invalid without test special seal.

2. Testing report is invalid without compiler, checker and approver's signature.

3. Please inform CTQC in time after received the testing report if you have some disagreement to the testing report.

4. Testing or witnessing only apply to sample.

5. Copying testing certificate or testing report is forbidden without written permission from CTQC (except for copying all the testing report).

Test Report		№: CTQC/ZJ-23.0045 Total 22 Page 3		
Test results				
№	Test items	Specified values	Measured values	Conclusions
		Standards (Technical contract)		
1	Measurement of dielectric dissipation factor ( $\tan\delta$ ) and capacitances at ambient temperature (Before type test)	Applied voltage(kV): 2~20 $\tan\delta: \leq 0.007$ Providing capacitance of the sample(pF)	10.0 0.00301 395.0	Passed
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ $\tan\delta: \leq 0.007$ Providing capacitance of the sample(pF)	76.4 0.00347 395.4	
		Applied voltage(kV): $U_m$ $\tan\delta: \leq 0.007$ Providing capacitance of the sample(pF)	126 0.00360 395.5	
2	Measurement of partial discharge quantity (Before type test)	Applied voltage(kV): $U_m$ Partial discharge level(pC): $\leq 10$	126 <6	Passed
		Applied voltage(kV): $1.5U_m/\sqrt{3}$ Partial discharge level(pC): $\leq 10$	109.1 <6	
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ Partial discharge level(pC): $\leq 5$	76.4 <4	
3	Visual inspection and dimensions check (Type test)	According to standard	See 4.3	Passed
4	Dry lightning impulse voltage withstand test (Type test)	Full wave voltage Positive polarity(kV): 525.5 (Corrected value) $\pm 3\%$ Negative polarity(kV):605 $\pm 3\%$ 15 positive and 15 negative polarity Chopped wave voltage (kV): 665.5 $\pm 3\%$ 5 negative polarity	523.15~525.73 607.90~619.07 Each 15 times 665.46~669.55 5 times	Passed
5	Wet power-frequency voltage withstand test (Type test)	Applied voltage(kV): 231.2 (Corrected value) Duration(s): 60	231.2 60	Passed
6	Long-duration power-frequency voltage withstand test (ACLD) (Type test)	$U_1=U_m$ (kV) Duration(s): 60	126 60	Passed
		$U_2=1.5U_m/\sqrt{3}$ Duration(min): 60 Partial discharge level(pC): $\leq 10$	109.1 60 <5	
		$1.1U_m/\sqrt{3}$ (kV) Duration(min): 5 Partial discharge level(pC): $\leq 5$	80 5 <4	

Test Report		№: CTQC/ZJ-23.0045 Total 22 Page 4			
№	Test items	Specified values		Measured values	Conclusions
		Standards (Technical contract)			
7	Radio interference voltage test (Type test)	Applied voltage(kV): $1.1U_m/\sqrt{3}$ Duration(min): 5 Radio interference level( $\mu$ V): $\leq 500$		80 5 282	Passed
8	Temperature rise test (Type test)	Temperature limit( $^{\circ}$ C): 120 Temperature rise limit(K): 75		42.8~73.0 31.5~61.7	Passed
9	Verification of thermal short-time current withstand (Type test)	Thermal short-time current(kA): $25I_r$ Duration(s): 2 Final temperature of the conductor ( $^{\circ}$ C): $\leq 180$		40 2 128.4	Passed
10	Cantilever load withstand test (Type test)	Applied load(N): 3150 Duration(s): 60 Successfully repeat check items		3236 60 Passed	Passed
11	Measurement of partial discharge quantity (After type test)	Applied voltage(kV): $U_m$ Partial discharge level(pC): $\leq 10$		126 <6	Passed
		Applied voltage(kV): $1.5U_m/\sqrt{3}$ Partial discharge level(pC): $\leq 10$		109.1 <5	
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ Partial discharge level(pC): $\leq 5$		76.4 <5	
12	Measurement of dielectric dissipation factor ( $\tan\delta$ ) and capacitances at ambient temperature (After type test)	Applied voltage(kV): 2~20 $\tan\delta$ : $\leq 0.007$ Providing capacitance of the sample(pF)		10.0 0.00300 391.4	Passed
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ $\tan\delta$ : $\leq 0.007$ Providing capacitance of the sample(pF)		76.4 0.00330 391.7	
		Applied voltage(kV): $U_m$ $\tan\delta$ : $\leq 0.007$ Providing capacitance of the sample(pF)		126 0.00345 391.7	
13	Visual inspection and dimensions check (Routine test)	According to standard		See 4.13	Passed
14	Tests of tap insulation (Routine test)	Dry power-frequency voltage withstand test on the tap: Applied voltage(kV): $\geq 2$ Duration(s): 60		3 60	Passed
		Measurement of dielectric dissipation factor ( $\tan\delta$ ) and capacitances at ambient temperature on the tap: Applied voltage(kV): $\geq 1$ $\tan\delta$ : $\leq 0.05$ Capacitance(pF): $\leq 10000$		2 0.00323 315.8	

Test Report		No: CTQC/ZJ-23.0045 Total 22 Page 5		
№	Test items	Specified values	Measured values	Conclusions
		Standards (Technical contract)		
15	Dry lightning impulse voltage withstand test (Routine test)	Full wave voltage(kV): 577.5 ±3% 3 negative polarity Chopped wave voltage(kV): 632.5 ±3% 2 negative polarity	575.81~579.11 3 times 629.40~629.97 2 times	Passed
16	Dry power-frequency voltage withstand test (Routine test)	Applied voltage(kV): 255 Duration(s): 60	255 60	Passed
17	Tightness test at the flange (Routine test)	Applied medium Applied pressure(MPa): 0.4 ±0.01 Duration(min): 15 No leakage and damage	Compressed air 0.4 15 No leakage and damage	Passed
18	Measurement of partial discharge quantity (Routine test)	Applied voltage(kV): $U_m$ Partial discharge level(pC): $\leq 10$	126 <5	Passed
		Applied voltage(kV): $1.5U_m/\sqrt{3}$ Partial discharge level(pC): $\leq 10$	109.1 <5	
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ Partial discharge level(pC): $\leq 5$	76.4 <5	
19	Measurement of dielectric dissipation factor ( $\tan\delta$ ) and capacitances at ambient temperature (Routine test)	Applied voltage(kV): 2~20 $\tan\delta: \leq 0.007$ Providing capacitance of the sample(pF)	10.0 0.00301 391.4	Passed
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ $\tan\delta: \leq 0.007$ Providing capacitance of the sample(pF)	76.4 0.00329 391.7	
		Applied voltage(kV): $U_m$ $\tan\delta: \leq 0.007$ Providing capacitance of the sample(pF)	126 0.00345 391.7	
Note: 1. All the tests were field tests; 2. Tested in Shandong Qixing High Voltage Electric Co., Ltd. laboratory.				

Test Report		No: CTQC/ZJ-23.0045 Total 22 Page 6
<p>1. Test object parameters</p> <p>Highest voltage for equipment(kV): 126</p> <p>Rated phase to earth voltage(kV): <math>126/\sqrt{3}</math></p> <p>Rated current(A): 1600</p> <p>Rated frequency(Hz): 50</p> <p>Altitude(m): <math>\leq 1000</math></p> <p>Thermal class of insulation: E</p> <p>Test tap(measured tap, <math>\tan\delta</math>): With</p> <p>Insulation type of bushing: Adhesive paper</p> <p>2. Sample condition description</p> <p>Sample exterior construction and major dimensions(length, diameter) are in compliance with outline drawings.</p> <p>Measured values: length 2497mm, outer diameter <math>\Phi 400</math>mm.</p>		
Outline dimensions	Rating plate	
PCB11-620	8QX.860.008G	
<p>Rating plate and outline drawings see testing report annex.</p> <p>The form, performance data, specifications of sample rating plate are in compliance with drawing.</p> <p>The surface of the sample has no collision and damage.</p> <p>3. Standards</p> <p>IEC60137:2017, GB/T4109-2008 Insulated bushings for alternating voltage above 1000V</p> <p>Technical contract</p>		

Test Report			No: CTQC/ZJ-23.0045 Total 22 Page 7	
4. Test items and conclusions				
4.1 Measurement of dielectric dissipation factor ( $\tan \delta$ ) and capacitances at ambient temperature (Before type test) <span style="float: right;">Test date: Feb. 17, 2023 Humidity: 43.0%; Ambient temperature: 11.6°C</span>				
Applied voltage (kV)	Dielectric dissipation factor ( $\tan \delta$ )	Capacitance(pF)	Result	
10.0	0.00301	395.0	Passed	
76.4	0.00347	395.4		
126.0	0.00360	395.5		
Note: $\tan \delta(126\text{kV}) - \tan \delta(76.4\text{kV}) = 0.00013 < 0.001$ (Standard value), passed.				
4.2 Measurement of partial discharge quantity (Before type test) <span style="float: right;">Test date: Feb. 17, 2023 Humidity: 43.0%; Ambient temperature: 11.6°C; Atmospheric pressure: 101.6kPa</span>				
Prestress voltage (kV)	Duration(s)	Measured voltage (kV)	Partial discharge level (pC)	Result
255	60	126.0	<6	Passed
		109.1	<6	
		76.4	<4	
		126.0	<6	
Note: Background noise level was <4pC before and after test.				
4.3 Visual inspection and dimensional check (Type test) <span style="float: right;">Test date: Feb. 17, 2023</span>				
It has smooth surface, no cracks. Dimensional check is accordance with the drawing requirement.				
Drawing values(mm): 2495 ± 20   1140 ± 10   835 ± 5   Ø400   100				
Measured values(mm): 2497   1150   838   Ø400   100				
Arcing distance(mm): 1200   Creepage distance(mm): 4585				
Result: Passed.				

## Test Report

No: CTQC/ZJ-23.0045

Total 22 Page 8

4.4 Dry lightning impulse voltage withstand test (Type test)

Test date: Feb. 21, 2023

Test atmospheric conditions

Humidity: 46.0%; Ambient temperature: 12.1°C; Atmospheric pressure: 101.08kPa.

Rated lightning impulse withstand voltage:

Positive: 525.5kV (Corrected value)

Negative: 605kV

15 positive and 15 negative polarity

Chopped lightning impulse withstand voltage: 665.5kV

5 negative polarity

Test sequence

One positive reference full wave impulse;

Fifteen positive rated full wave impulses;

One negative reference full wave impulse;

One negative rated full wave impulse;

Five negative rated chopped wave impulses;

Fourteen negative rated full wave impulses.

Test oscillogram records

T1: Front time;

T2: Time to half value;

UpMax/UpMin: Peak voltage;

Tc: Time to chopping;

K: Factor of over crossing.

Result: Passed.

## Test Report









No: CTQC/ZJ-23.0045

Total 22 Page 9

Tested terminal: To earth

Test polarity: Positive

CH1: Voltage wave



## Test Report









No: CTQC/ZJ-23.0045

Total 22 Page 10

Tested terminal: To earth

Test polarity: Positive

CH1: Voltage wave



## Test Report


No: CTQC/ZJ-23.0045

Total 22 Page 11


Tested terminal: To earth

Test polarity: Positive


CH1: Voltage wave




TimeBase:10.00µs/Trigger:Ch2  
Ch2: 100.00kV




TimeBase:10.00µs/Trigger:Ch2  
Ch2: 180.00kV




TimeBase:4.00µs/Trigger:Ch2  
Ch2: 180.00kV




TimeBase:4.00µs/Trigger:Ch2  
Ch2: 180.00kV



TimeBase:4.00µs/Trigger:Ch2  
Ch2: 180.00kV



TimeBase:4.00µs/Trigger:Ch2  
Ch2: 180.00kV



TimeBase:4.00µs/Trigger:Ch2  
Ch2: 180.00kV

## Test Report









No: CTQC/ZJ-23.0045

Total 22 Page 12

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage wave



## Test Report







No: CTQC/ZJ-23.0045

Total 22 Page 13

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage wave



Test Report				No.: CTQC/ZJ-23. 0045 Total 22 Page 14		
4.5 Wet power-frequency voltage withstand test (Type test)				Test date: Feb. 21, 2023		
Humidity: 46.0%; Ambient temperature: 12.1°C; Atmospheric pressure: 101.8kPa						
Applied position	Applied voltage(kV)			Frequency (Hz)	Duration (s)	Result
	Standard value	Atmospheric corrected value	Applied value			
Terminals-earth	230	231.2	231.2	50	60	Passed
<p>Note: The conductivity of collected water is 100.9<math>\mu</math>S/cm at 20°C. The average precipitation rate: Vertical component 1.3mm/min, horizontal component 1.2mm/min.</p>						
4.6 Long-duration power-frequency withstand voltage test (AGLD) (Type test)				Test date: Feb. 22, 2023		
				Ambient temperature: 11.4°C		
Applied voltage		Duration(min)	Partial discharge level(pC)			
Multiple	Phase-earth(kV)					
$1.1U_m/\sqrt{3}$	80	5	<4			
$U_2=1.5U_m/\sqrt{3}$	109.1	5	<4			
$U_1=U_m$	126	1	/			
$U_2=1.5U_m/\sqrt{3}$	109.1	5	<4			
		10	<5			
		15	<5			
		20	<5			
		25	<5			
		30	<5			
		35	<5			
		40	<5			
		45	<5			
		50	<5			
55	<5					
60	<5					
$1.1U_m/\sqrt{3}$	80	5	<4			
<p>Note: <math>U_m=126kV</math>; Background level is &lt;4pC before and after test. Result: Passed.</p>						

Test Report	No: CTQC/ZJ-23.0045 Total 22 Page 15
-------------	---

4.7 Radio interference voltage test (Type test)


Test date: Feb. 22, 2023

Humidity: 40.0%; Ambient temperature: 11.4°C; Atmospheric pressure: 100.2kPa

Measured frequency (MHz)	Attenuation factor of measurement circuit (dB)	Attenuation factor of resistance network (dB)	Measured voltage (kV)	Duration (min)	Radio interference reading $B_m$ (dB)	Radio interference level ( $\mu V$ )
1.0	14	22	80	5	13	282
			72.7	/	13	282
			65.5		13	282
			58.2		12	251
			50.9		12	251
			43.6		12	251
			36.4		11	224
			29.1		11	224
			21.8		11	224

Result: Passed.

Radio interference curve




Test Report				№: CTQC/ZJ-23. 0045 Total 22 Page 16		
4.8 Temperature rise test (Type test)				Test date: Feb. 22, 2023		
Specified current was 1600A, injected current was 1600A during test, the test duration was 6h, stability duration was 1h.						
Calculated result of temperature rise						
№.	Measured position	Temperature of bushing (°C)	Temperature rise of bushing (K)	Ambient temperature (°C)	Oil temperature (°C)	Result
1	Terminal in the air	62.1	50.8	11.3	71.5	Passed
2	Firmness of terminal in the air	55.6	44.3			
3	Conducting rod top part	42.8	31.5			
4	Conducting rod middle part	54.2	42.9			
5	Flange	51.9	40.6			
6	Conducting rod tail part	73.0	61.7			
The schematic diagram of measured points shown in page 17.						

Test Report

No: CTQC/ZJ-23.0045

Total 22 Page 17

Schematic diagram of measured point of temperature rise



- 1. Terminal in the air
- 2. Firmness of terminal in the air
- 3. Conducting rod top part
- 4. Conducting rod middle part
- 5. Flange
- 6. Transformer oil
- 7. Conducting rod tail part

Test Report		No: CTQC/ZJ-23.0045 Total 22 Page 18
<p>4.9 Verification of thermal short-time current withstand(Verified by the calculation) (Type test) <span style="float: right;">Test date: Feb. 23, 2023</span></p> <p>The standard value of thermal short-time current of bushing <math>I_{th}=40\text{kA}</math>, duration was 2s. According to calculation final temperature of the conductor <math>\theta_f=128.4^\circ\text{C}</math>. If <math>\theta_f \leq 180^\circ\text{C}</math>, it was considered that the bushing could withstand the standard value <math>I_{th}</math> of thermal short-time current.</p>		
Sample parameters		
Conductor material of sample	Copper	
Conductor resistivity $\rho(\mu\Omega\cdot\text{cm})$	1.75	
Total cross section area $S_t(\text{cm}^2)$	11.3354	
Measured temperature rise of the bushing(K)	61.7	
Rated current $I_r(\text{A})$	1600	
Standard value of rated thermal short-time current $I_{th}(\text{kA})$	40	
Rated duration(s)	2	
$\theta_0(^\circ\text{C})$	101.7	
Current penetration depth $d(\text{cm})$	0.942	
Diameter of the conductor $D(\text{cm})$	3.8	
$\alpha[(\text{K/s})/(\text{kA}/\text{cm}^2)^2]$	0.8	
Equivalent cross section area considering the skin effect $S_e(\text{cm}^2)$	8.4536	
<p>Verify by the calculation:</p> $\theta_f = \theta_0 + \alpha \frac{I_{th}^2}{S_t \times S_e} t_{th} = 128.4^\circ\text{C}$		
Result: Passed.		

Test Report						No.: CTQC/ZJ-23.0045 Total 22 Page 19
4.10 Cantilever load withstand test (Type test)						Test date: Feb. 23, 2023
Load direction	Applied position	Standard value		Applied value		Result
		Load(N)	Duration(s)	Load(N)	Duration(s)	
Vertical	Terminal	3150	60	3236	60	No damage, distortion, passed.
4.11 Measurement of partial discharge quantity (After type test)						Test date: Feb. 23, 2023 Humidity: 41.0%; Ambient temperature: 11.8°C; Atmospheric pressure: 101.8kPa
Prestress voltage (kV)	Duration(s)	Measured voltage(kV)	Partial discharge level(pC)	Result		
255	60	126	<6	Passed		
		109.1	<5			
		76.4	<5			
Note: Background noise level was <5pC before and after test.						
4.12 Measurement of dielectric dissipation factor ( $\tan \delta$ ) and capacitances at ambient temperature (After type test)						Test date: Feb. 23, 2023 Humidity: 41.0%; Ambient temperature: 11.8°C
Applied voltage(kV)	Dielectric dissipation factor( $\tan \delta$ )	Capacitance (pF)	Result			
10	0.00300	391.4	Passed			
76.4	0.00330	391.7				
126	0.00345	391.7				
Note: $\tan \delta(126\text{kV}) - \tan \delta(76.4\text{kV}) = 0.00015 < 0.001$ (Standard value), passed.						
4.13 Visual inspection and dimensional check (Routine test)						Test date: Feb. 23, 2023
It has smooth surface, no cracks. Dimensional check is accordance with the drawing requirement. Dimensional check see 4.3. Result: Passed.						

Test Report				No.: CTQC/ZJ-23. 0045 Total 22 Page 20	
4. 14 Tests of tap insulation (Routine test)				Test date: Feb. 23, 2023	
Dry power-frequency voltage withstand test on the tap					
Humidity: 41.0%; Ambient temperature: 11.8°C; Atmospheric pressure: 101.8kPa					
Applied position	Applied voltage(kV)	Frequency(Hz)	Duration(s)	Result	
Tap-earth	3	50	60	Passed	
Measurement of dielectric dissipation factor (tan $\delta$ ) and capacitances at ambient temperature on the tap					
Humidity: 41.0%; Ambient temperature: 11.8°C					
Applied voltage(kV)	Dielectric dissipation factor(tan $\delta$ )	Capacitance(pF)	Result		
2	0.00323	315.8	Passed		
4. 15 Dry lightning impulse voltage withstand test (Routine test)				Test date: Feb. 23, 2023	
Test atmospheric conditions					
Humidity: 41.0%; Ambient temperature: 11.8°C; Atmospheric pressure: 101.8kPa.					
Rated lightning impulse withstand voltage: 577.5kV		3 negative polarity			
Chopped lightning impulse withstand voltage: 632.5kV		2 negative polarity			
Test sequence					
One negative reference full wave impulse;					
One negative rated full wave impulses;					
Two negative rated chopped wave impulses;					
Two negative rated full wave impulses.					
Test records:					
T1: Front time;		T2: Time to half value;		UpMax/UpMin: Peak voltage;	
Tc: Time to chopping;		K: Factor of over crossing.			
Result: Passed.					

## Test Report







No.: CTQC/ZJ-23.0045

Total 22 Page 21

Tested terminal: To earth

Test polarity: Negative


CH1: Voltage wave



Test Report					No.: CTQC/ZJ-23. 0045 Total 22 Page 22	
4.16 Dry power-frequency voltage withstand test (Routine test)					Test date: Feb. 23, 2023	
Humidity: 41.0%; Ambient temperature: 11.8°C; Atmospheric pressure: 101.8kPa						
Applied position	Applied voltage(kV)			Frequency (Hz)	Duration (s)	Result
	Standard value	Atmospheric corrected value	Applied value			
Terminals-earth	255	/	255	50	60	Passed
4.17 Tightness test at the flange (Routine test)					Test date: Feb. 23, 2023	
Applied pressure(MPa)	Duration(min)	Residual pressure(MPa)	Result			
0.4	15	0.4	No leakage and damage, passed.			
4.18 Measurement of partial discharge quantity (Routine test)					Test date: Feb. 23, 2023	
Humidity: 41.0%; Ambient temperature: 11.8°C; Atmospheric pressure: 101.8kPa						
Prestress voltage (kV)	Duration (s)	Measured voltage (kV)	Partial discharge level(pC)	Result		
255	60	126	<5	Passed		
		109.1	<5			
		76.4	<5			
Note: Background level was <5pC before and after test.						
4.19 Measurement of dielectric dissipation factor ( $\tan \delta$ ) and capacitances at ambient temperature (Routine test)					Test date: Feb. 23, 2023	
Humidity: 41.0%; Ambient temperature: 11.8°C; Atmospheric pressure: 101.8kPa						
Applied voltage(kV)	Dielectric dissipation factor( $\tan \delta$ )	Capacitance(pF)	Result			
10	0.00301	391.4	Passed			
76.4	0.00329	391.7				
126	0.00345	391.7				
Note: $\tan \delta(126\text{kV}) - \tan \delta(76.4\text{kV}) = 0.00016 < 0.001$ (Corrected value), passed.						

RATING PLATE AND OUTLINE PHOTOS





Rating plate:



Outline:



BUSHING DRAWINGS



雷电冲击 550kV  
 工频耐受电压 255kV/1min  
 局部放电 126kV $\leq$ 10pC  
 介质损耗因数 $<$ 0.4%  
 爬电比距 31mm/kV (爬距 $\geq$ 3906mm)  
 海拔高度  $\leq$ 1000m  
 抗弯负荷: 3150N  
 其他要求符合最新版GB/T4109和IEC60137的规定

标记	处数	分区	更改文件号	签名	年、月、日	QXBRP (G) WD-L-126/1600-4		山东七星高压电气有限公司			
设计	张学明	2023.2.2	标准化			胶浸纸变压器套管外形图		图号: PCB11-620			
审核	石孝刚	2023.2.2				阶段标记		重量		比例	
工艺			批准	曹明波	2023.2.2	共 张 第 张		1:10		产品品号: PCBT620	



# CHPTL

中国大容量试验联盟(简称 CHPTL)是中国同类试验机构的唯一协作组织, 隶属于中国电工技术学会. 其主要目标是规范国家标准、行业标准及 IEC 标准在电力设备(交流 1000V 以上, 直流 1200V 以上)型式试验中的协调应用.

China High Power Testing liaison (CHPTL) is the only organization in China which is formed to promote and coordinate the application of IEC/GB standard as well as industry standards in power electrical equipment type test (AC above 1000V, DC above 1200V). CHPTL is under the leadership and management of China Electro-technical Society.

CHPTL 成员单位如下:

The members of CHPTL are as follows:

西安高压电器研究院有限责任公司(XIHARI)

Xi'an High Voltage Apparatus Research Institute Co., Ltd. (XIHARI)

中国电力科学研究院(CEPRI)

China Electrical Power Research Institute (CEPRI)

辽宁高压电器产品质量检测有限公司(AQTC)

Liaoning High Voltage Apparatus Quality Test Co., Ltd. (AQTC)

沈阳变压器研究院有限公司变压器实验室(STRI)

Shenyang Transformer Institute Co., Ltd Transformer Laboratory (STRI)

上海电气输配电试验中心有限公司(SETC)

Shanghai Electric Power Transmission & Distribution Testing Center Co., Ltd. (SETC)

电力工业无功补偿成套装置质量检验测试中心(PRCIQTC)

Power Industry Reactive Compensation Equipment Quality Inspection & Test Center(PRCIQTC)

CHPTL 作为一个协作组织, 本身并不出具型式试验报告. 每一个 CHPTL 成员对其出具的型式试验报告的有效性和内容负责.

CHPTL as a collaboration does not itself issue test reports. Each CHPTL member issuing a test report is responsible for the validity and contents of that report.