



230008349512



中国认可
国际互认
检测
TESTING
CNAS L0681



CHPTL

TEST REPORT

No : CTQC/ZJ-23. 0043

Test object name: Adhesive paper capacitive transformer
bushing

Test object type: QXBRP(G)WD-L-252/1600-4

Entrusted by: Shandong Qixing High Voltage Electric
CO., Ltd.

Manufacturer: Shandong Qixing High Voltage Electric
CO., Ltd.

Kind of testing: Type tests



SHENYANG TRANSFORMER RESEARCH INSTITUTE CO., LTD.

CHINA NATIONAL TRANSFORMER QUALITY DETECTION AND TESTING CENTER

CX-F-01	Test Report	No: CTQC/ZJ-23.0043 Total 27 Page 1
---------	-------------	--

CONTENTS

	Page
1. Test report cover	
2. Contents.....	1
3. Signing and issuing.....	2
4. Test results.....	3~5
5. Test object parameters.....	6
6. Sample condition description.....	6
7. Standards	6
8. Test items and conclusions.....	7~27
9. Annex 1: Rating plate and outline photo(Total page 1)	
10. Annex 2: Bushing drawings(Total pages 2)	

Shenyang Transformer Research Institute Co., Ltd.

China National Transformer Quality Detection And Testing Center

Test Report

No: CTQC/ZJ-23.0043

Total 27 Page 2

Test object name	Adhesive paper capacitive transformer bushing	Test object type	QXBRP(G)WD-L-252/1600-4
		Brand	/
Entrusted by	Shandong Qixing High Voltage Electric Co., Ltd.	Kind of testing	Type tests
Manufacturer	Shandong Qixing High Voltage Electric Co., Ltd.	Sampling date	/
		Test date	Feb. 19, 2023~Feb. 24, 2023
Address	No. 1228, Pengcheng Industrial Park, Pingli Road, Xiazhuang Town, Gaomi City, Weifang City, Shandong Province	Serial No	2302PB002
Standards	IEC60137: 2017 GB/T4109-2022 Technical contract	Test items	Routine tests Type tests
Results	The test results of routine tests, type tests of QXBRP(G)WD-L-252/1600-4 are in accordance with standards and technical contract. The sample passed the above tests.		
Note	  <p>Signing and issuing date: 2023.03.07</p>		

Approved by: Lv Xiangpeng

Checked by: Du Jiansong

Compiled by: Jiang Anping

- Statement:
1. Testing report is invalid without test special seal.
 2. Testing report is invalid without compiler, checker and approver's signature.
 3. Please inform CTQC in time after received the testing report if you have some disagreement to the testing report.
 4. Testing or witnessing only apply to sample.
 5. Copying testing certificate or testing report is forbidden without written permission from CTQC (except for copying all the testing report).

Test Report			№: CTQC/ZJ-23.0043 Total 27 Page 3	
Test results				
№	Test items	Specified values	Measured values	Conclusions
		Standards (Technical contract)		
1	Measurement of dielectric dissipation factor ($\tan\delta$) and capacitances at ambient temperature (Before type test)	Applied voltage(kV): 2~20 $\tan\delta$: ≤ 0.007 Providing capacitance of the sample(pF)	10.0 0.00298 570.9	Passed
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ $\tan\delta$: ≤ 0.007 Providing capacitance of the sample(pF)	152.8 0.00369 571.6	
		Applied voltage(kV): U_m $\tan\delta$: ≤ 0.008 Providing capacitance of the sample(pF)	252 0.00392 571.6	
2	Measurement of partial discharge quantity (Before type test)	Applied voltage(kV): U_m Partial discharge level(pC): ≤ 10	252 <6	Passed
		Applied voltage(kV): $1.5U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 10	218.2 <5	
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 5	152.8 <5	
3	Visual inspection and dimensions check (Type test)	According to standard	See 4.3	Passed
4	Dry lightning impulse voltage withstand test (Type test)	Full wave voltage Positive polarity(kV): 994.1(Corrected value) $\pm 3\%$ Negative polarity(kV): 1155 $\pm 3\%$ 15 positive and 15 negative polarity Chopped wave voltage (kV): 1270.5 $\pm 3\%$ 5 negative polarity	969.99~996.20 1169.11~1180.09 Each 15 times 1247.03~1253.08 5 times	Passed
5	Dry switching impulse voltage withstand test (Type test)	Full wave voltage Positive polarity(kV): 816.6(Corrected value) $\pm 3\%$ Negative polarity(kV): 935 $\pm 3\%$ 15 positive and 15 negative polarity	808.59~815.69 917.10~930.94 Each 15 times	Passed
6	Wet power-frequency voltage withstand test (Type test)	Applied voltage(kV): 462.8(Corrected value) Duration(s): 60	462.8 60	Passed

Test Report		№: CTQC/ZJ-23.0043 Total 27 Page 4		
№	Test items	Specified values	Measured values	Conclusions
		Standards (Technical contract)		
7	Long-duration power-frequency voltage withstand test (ACLD) (Type test)	U ₁ =U _m (kV) Duration(s): 60	252 60	Passed
		U ₂ =1.5U _m /√3 Duration(min): 60 Partial discharge level(pC): ≤10	218.2 60 <5	
		1.1U _m /√3 (kV) Duration(min): 5 Partial discharge level(pC): ≤5	160 5 <5	
8	Radio interference voltage test (Type test)	Applied voltage(kV): 1.1U _m /√3 Duration(min): 5 Radio interference level(μV): ≤500	160 5 316	Passed
9	Temperature rise test (Type test)	Temperature limit(°C): 120 Temperature rise limit(K): 75	46.6~78.9 35.1~67.4	Passed
10	Verification of thermal short-time current withstand (Type test)	Thermal short-time current(kA): 25I _r Duration(s): 2 Final temperature of the conductor (°C): ≤180	40 2 134.1	Passed
11	Cantilever load withstand test (Type test)	Applied load(N): 4000 Duration(s): 60 Successfully repeat check items	4108 60 Passed	Passed
12	Measurement of partial discharge quantity (After type test)	Applied voltage(kV): U _m Partial discharge level(pC): ≤10	252 <5	Passed
		Applied voltage(kV): 1.5U _m /√3 Partial discharge level(pC): ≤10	218.2 <4	
		Applied voltage(kV): 1.05U _m /√3 Partial discharge level(pC): ≤5	152.8 <4	
13	Measurement of dielectric dissipation factor (tanδ) and capacitances at ambient temperature (After type test)	Applied voltage(kV): 2~20 tanδ: ≤0.007 Providing capacitance of the sample(pF)	10.0 0.00296 571.0	Passed
		Applied voltage(kV): 1.05U _m /√3 tanδ: ≤0.007 Providing capacitance of the sample(pF)	152.8 0.00370 571.6	
		Applied voltage(kV): U _m tanδ: ≤0.008 Providing capacitance of the sample(pF)	252 0.00393 571.6	

Test Report			No.: CTQC/ZJ-23.0043 Total 27 Page 5	
№	Test items	Specified values	Measured values	Conclusions
		Standards (Technical contract)		
14	Visual inspection and dimensions check (Routine test)	According to standard	See 4.14	Passed
15	Tests of tap insulation (Routine test)	Dry power-frequency voltage withstand test on the tap: Applied voltage(kV): ≥ 2 Duration(s): 60	3 60	Passed
		Measurement of dielectric dissipation factor ($\tan\delta$) and capacitances at ambient temperature on the tap: Applied voltage(kV): ≥ 1 $\tan\delta$: ≤ 0.05 Capacitance(pF): ≤ 10000	2 0.00498 696.3	
16	Dry lightning impulse voltage withstand test (Routine test)	Full wave voltage(kV): 1102.5 $\pm 3\%$ 3 negative polarity	1090.71~1095.52 3 times	Passed
		Chopped wave voltage(kV): 1207.5 $\pm 3\%$ 2 negative polarity	1193.78~1193.97 2 times	
17	Dry power-frequency voltage withstand test (Routine test)	Applied voltage(kV): 505 Duration(s): 60	505 60	Passed
18	Tightness test at the flange (Routine test)	Applied medium Applied pressure(MPa): 0.4 ± 0.01 Duration(min): 15 No leakage and damage	Compressed air 0.4 15 No leakage and damage	Passed
19	Measurement of partial discharge quantity (Routine test)	Applied voltage(kV): U_m Partial discharge level(pC): ≤ 10	252 <5	Passed
		Applied voltage(kV): $1.5U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 10	218.2 <5	
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 5	152.8 <4	
20	Measurement of dielectric dissipation factor ($\tan\delta$) and capacitances at ambient temperature (Routine test)	Applied voltage(kV): 2~20 $\tan\delta$: ≤ 0.007 Providing capacitance of the sample(pF)	10.0 0.00296 571.0	Passed
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ $\tan\delta$: ≤ 0.007 Providing capacitance of the sample(pF)	152.8 0.00367 571.5	
		Applied voltage(kV): U_m $\tan\delta$: ≤ 0.008 Providing capacitance of the sample(pF)	252 0.00392 571.6	
Note: 1. All the tests were field tests; 2. Tested in Shandong Qixing High Voltage Electric Co., Ltd. laboratory.				

Test Report		No: CTQC/ZJ-23.0043 Total 27 Page 6
<p>1. Test object parameters</p> <p>Highest voltage for equipment(kV): 252</p> <p>Rated phase to earth voltage(kV): $252/\sqrt{3}$</p> <p>Rated current(A): 1600</p> <p>Rated frequency(Hz): 50</p> <p>Altitude(m): ≤ 1000</p> <p>Thermal class of insulation: E</p> <p>Test tap(measured tap, $\tan\delta$): With</p> <p>Insulation type of bushing: Adhesive paper</p> <p>2. Sample condition description</p> <p>Sample exterior construction and major dimensions(length, diameter) are in compliance with outline drawings.</p> <p>Measured values: length 4285mm, outer diameter $\Phi 550$mm.</p>		
Outline dimensions	Rating plate	
PCB22-920	8QX.860.008G	
<p>Rating plate and outline drawings see testing report annex.</p> <p>The form, performance data, specifications of sample rating plate are in compliance with drawing.</p> <p>The surface of the sample has no collision and damage.</p> <p>3. Standards</p> <p>IEC60137:2017, GB/T4109-2008 Insulated bushings for alternating voltage above 1000V</p> <p>Technical contract</p>		

Test Report		No: CTQC/ZJ-23.0043 Total 27 Page 7		
4. Test items and conclusions				
4.1 Measurement of dielectric dissipation factor ($\tan \delta$) and capacitances at ambient temperature (Before type test) Test date: Feb. 19, 2023 Humidity: 39.0%; Ambient temperature: 11.2°C				
Applied voltage (kV)	Dielectric dissipation factor ($\tan \delta$)	Capacitance(pF)	Result	
10	0.00298	570.9	Passed	
152.8	0.00369	571.6		
252	0.00392	571.6		
Note: $\tan \delta(252\text{kV}) - \tan \delta(152.8\text{kV}) = 0.00023 < 0.001$ (Standard value), passed.				
4.2 Measurement of partial discharge quantity (Before type test) Test date: Feb. 19, 2023 Humidity: 39.0%; Ambient temperature: 11.2°C; Atmospheric pressure: 101.9kPa				
Prestress voltage (kV)	Duration(s)	Measured voltage (kV)	Partial discharge level (pC)	Result
505	60	252.0	<6	Passed
		218.2	<5	
		152.8	<5	
Note: Background noise level was < 5pC before and after test.				
4.3 Visual inspection and dimensional check (Type test) Test date: Feb. 19, 2023				
It has smooth surface, no cracks. Dimensional check is accordance with the drawing requirement.				
Drawing values(mm): 4270±20 2265±10 1290±5 Ø550 100				
Measured values(mm): 4285 2270 1291 Ø550 100				
Arcing distance(mm): 2290 Creepage distance(mm): 9600				
Result: Passed.				

Test Report

No: CTQC/ZJ-23.0043

Total 27 Page 8

4.4 Dry lightning impulse voltage withstand test (Type test)

Test date: Feb. 21, 2023

Test atmospheric conditions

Humidity: 37.0%; Ambient temperature: 11.5°C; Atmospheric pressure: 102.1kPa.

Rated lightning impulse withstand voltage(kV): Positive: 994.1(Corrected value)

Negative: 1155 15 positive and 15 negative polarity

Chopped lightning impulse withstand voltage(kV): 1270.5 5 negative polarity

Test sequence

One positive reference full wave impulse;

Fifteen positive rated full wave impulses;

One negative reference full wave impulse;

One negative rated full wave impulse;

Five negative rated chopped wave impulses;

Fourteen negative rated full wave impulses.

Test oscillogram records

T1: Front time;

T2: Time to half value;

Up_{MAX}/ Up_{MIN}: Peak voltage;

Tc: Time to chopping;

K: Factor of over crossing.

Result: Passed.

Test Report









No: CTQC/ZJ-23.0043

Total 27 Page 9

Tested terminal: To earth

Test polarity: Positive

CH1: Voltage wave



Test Report









No: CTQC/ZJ-23.0043

Total 27 Page 10

Tested terminal: To earth

Test polarity: Positive

CH1: Voltage wave










Test Report

No: CTQC/ZJ-23.0043

Total 27 Page 11

Tested terminal: To earth
 Test polarity: Negative
 CH1: Voltage wave



Test Report









No: CTQC/ZJ-23.0043

Total 27 Page 12

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage wave



Test Report







No: CTQC/ZJ-23.0043

Total 27 Page 13

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage



Test Report

No: CTQC/ZJ-23.0043

Total 27 Page 14

4.5 Dry switching impulse voltage withstand test (Type test)

Test date: Feb. 21, 2023

Test atmospheric conditions

Humidity: 37.0%; Ambient temperature: 11.5°C; Atmospheric pressure: 102.1kPa.

Dry switching wave rated withstand voltage

Positive(kV): 816.6 (Corrected value)

Negative(kV): 935 15 positive and 15 negative polarity

Test sequence

One positive reference full wave impulse;

Fifteen positive rated full wave impulses;

One negative reference full wave impulse;

Fifteen negative rated full wave impulse.

Test oscillogram records

Tp: Front time; T2: Time to half value; U_{pMAX}/U_{pMIN} : Peak voltage.

Result: Passed.

Test Report









No: CTQC/ZJ-23.0043

Total 27 Page 15

Tested terminal: To earth

Test polarity: Positive

CH1: Voltage wave



Test Report









No.: CTQC/ZJ-23.0043

Total 27 Page 16

Tested terminal: To earth

Test polarity: Positive

CH1: Voltage wave



Test Report









No : CTQC/ZJ-23. 0043

Total 27 Page 17

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage wave



Test Report









No : CTQC/ZJ-23. 0043

Total 27 Page 18

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage wave



Test Report				No.: CTQC/ZJ-23. 0043 Total 27 Page 19		
4.6 Wet power-frequency voltage withstand test (Type test)				Test date: Feb. 21, 2023		
Humidity: 37.0%; Ambient temperature: 11.5°C; Atmospheric pressure: 102.1kPa						
Applied position	Applied voltage(kV)			Frequency (Hz)	Duration (s)	Result
	Standard value	Atmospheric corrected value	Applied value			
Terminals-earth	460.0	462.8	462.8	50	60	Passed
<p>Note: The conductivity of collected water is 100.4μS/cm at 20°C. The average precipitation rate: Vertical component 1.3mm/min, horizontal component 1.1mm/min.</p>						
4.7 Long-duration power-frequency withstand voltage test (ACLD) (Type test)				Test date: Feb. 23, 2023		
Ambient temperature: 11.8°C						
Applied voltage		Duration(min)	Partial discharge level(pC)			
Multiple	Phase-earth(kV)					
$1.1U_m/\sqrt{3}$	160.0	5	<5			
$U_2=1.5U_m/\sqrt{3}$	218.2	5	<5			
$U_1=U_m$	252.0	1	/			
$U_2=1.5U_m/\sqrt{3}$	218.2	5	<5			
		10	<5			
		15	<5			
		20	<5			
		25	<5			
		30	<5			
		35	<5			
		40	<5			
		45	<5			
		50	<5			
$1.1U_m/\sqrt{3}$	160.0	55	<5			
		60	<5			
$1.1U_m/\sqrt{3}$	160.0	5	<5			
<p>Note: $U_m=252kV$; Background level is <5pC before and after test. Result: Passed.</p>						

Test Report	No.: CTQC/ZJ-23. 0043 Total 27 Page 20
-------------	---

4.8 Radio interference voltage test (Type test)


Test date: Feb. 23, 2023

Humidity: 41.0%; Ambient temperature: 11.8°C; Atmospheric pressure: 101.8kPa

Measured frequency (MHz)	Attenuation factor of measurement circuit (dB)	Attenuation factor of resistance network (dB)	Measured voltage (kV)	Duration (min)	Radio interference reading B_m (dB)	Radio interference level (μV)
1.0	14	22	160.0	5	14	316
			145.5	/	14	316
			130.9		14	316
			116.4		14	316
			101.8		13	282
			87.3		13	282
			72.7		13	282
			58.2		13	282
			43.6		13	282

Result: Passed.

Radio interference curve



Test Report

№: CTQC/ZJ-23. 0043

Total 27 Page 21

4.9 Temperature rise test (Type test)

Test date: Feb. 23, 2023


Specified current was 1600A, injected current was 1600A during test, the test duration was 7h, stability duration was 1h.

Calculated result of temperature rise

№.	Measured position	Temperature of bushing (°C)	Temperature rise of bushing (K)	Ambient temperature (°C)	Oil temperature (°C)	Result
1	Terminal in the air	57.8	46.3	11.5	72.8	Passed
2	Junction cover in the air	53.1	41.6			
3	Conducting rod top part	57.4	45.9			
4	Conducting rod middle part	66.3	54.8			
5	Flange	46.6	35.1			
6	Conducting rod tail part	78.9	67.4			

The schematic diagram of measured points shown in page 22.

Schematic diagram of measured point of temperature rise



- 1. Terminal in the air
- 2. Junction over in the air
- 3. Conducting rod top part
- 4. Conducting rod middle part
- 5. Flange
- 6. Transformer oil
- 7. Conducting rod tail part

Test Report		No: CTQC/ZJ-23.0043 Total 27 Page 23
<p>4.10 Verification of thermal short-time current withstand(Verified by the calculation) (Type test) Test date: Feb. 24, 2023</p> <p>The standard value of thermal short-time current of bushing $I_{th}=40\text{kA}$, duration $t_{th}=2\text{s}$. According to calculation final temperature of the conductor $\theta_f=134.1^\circ\text{C}$. If $\theta_f \leq 180^\circ\text{C}$, it was considered that the bushing could withstand the standard value I_{th} of thermal short-time current.</p>		
Sample parameters		
Conductor material of sample	Copper	
Conductor resistivity $\rho(\mu\Omega\cdot\text{cm})$	1.75	
Total cross section area $S_t(\text{cm}^2)$	11.3354	
Measured temperature rise of the bushing(K)	67.4	
Rated current $I_r(\text{A})$	1600	
Standard value of rated thermal short-time current $I_{th}(\text{kA})$	40	
Rated duration(s)	2	
$\theta_0(^\circ\text{C})$	107.4	
Current penetration depth $d(\text{cm})$	0.942	
Diameter of the conductor $D(\text{cm})$	3.8	
$\alpha[(\text{K/s})/(\text{kA}/\text{cm}^2)^2]$	0.8	
Equivalent cross section area considering the skin effect $S_e(\text{cm}^2)$	8.4536	
<p>Verify by the calculation:</p> $\theta_f = \theta_0 + \alpha \frac{I_{th}^2}{S_t \times S_e} t_{th} = 134.1^\circ\text{C}$		
Result: Passed.		

Test Report						No.: CTQC/ZJ-23.0043 Total 27 Page 24
4.11 Cantilever load withstand test (Type test)						Test date: Feb. 24, 2023
Load direction	Applied position	Standard value		Applied value		Result
		Load(N)	Duration(s)	Load(N)	Duration(s)	
Vertical	Terminal	4000	60	4108	60	No damage, distortion, passed.
4.12 Measurement of partial discharge quantity (After type test)						Test date: Feb. 24, 2023
Humidity: 38.0%; Ambient temperature: 10.9°C; Atmospheric pressure: 101.6kPa						
Prestress voltage (kV)	Duration(s)	Measured voltage(kV)	Partial discharge level(pC)	Result		
505	60	252.0	<5	Passed		
		218.2	<4			
		152.8	<4			
Note: Background noise level was <4pC before and after test.						
4.13 Measurement of dielectric dissipation factor ($\tan \delta$) and capacitances at ambient temperature (After type test)						Test date: Feb. 24, 2023
Humidity: 38.0%; Ambient temperature: 10.9°C						
Applied voltage(kV)	Dielectric dissipation factor($\tan \delta$)	Capacitance (pF)	Result			
10	0.00296	571.0	Passed			
152.8	0.00370	571.6				
252	0.00393	571.6				
Note: $\tan \delta(252\text{kV}) - \tan \delta(152.8\text{kV}) = 0.00023 < 0.001$ (Standard value), passed.						
4.14 Visual inspection and dimensional check (Routine test)						Test date: Feb. 24, 2023
It has smooth surface, no cracks. Dimensional check is accordance with the drawing requirement. Dimensional check see 4.3.						
Result: Passed.						

Test Report				No: CTQC/ZJ-23. 0043 Total 27 Page 25	
4. 15 Tests of tap insulation (Routine test)				Test date: Feb. 24, 2023	
Dry power-frequency voltage withstand test on the tap					
Humidity: 38.0%; Ambient temperature: 10.9°C; Atmospheric pressure: 101.6kPa					
Applied position	Applied voltage(kV)	Frequency(Hz)	Duration(s)	Result	
Tap-earth	3	50	60	Passed	
Measurement of dielectric dissipation factor (tanδ) and capacitances at ambient temperature on the tap					
Humidity: 38.0%; Ambient temperature: 10.9°C					
Applied voltage(kV)	Dielectric dissipation factor(tanδ)	Capacitance(pF)	Result		
2	0.00498	519.7	Passed		
4. 16 Dry lightning impulse voltage withstand test (Routine test)				Test date: Feb. 24, 2023	
Test atmospheric conditions					
Humidity: 38.0%; Ambient temperature: 10.9°C; Atmospheric pressure: 101.6kPa.					
Rated lightning impulse withstand voltage(kV):		1102.5kV	3 negative polarity		
Chopped lightning impulse withstand voltage(kV):		1207.5kV	2 negative polarity		
Test sequence					
One negative reference full wave impulse;					
One negative rated full wave impulses;					
Two negative rated chopped wave impulses;					
Two negative rated full wave impulses.					
Test records					
T1: Front time;		T2: Time to half value;	Up _{MAX} / Up _{MIN} : Peak voltage;		
Tc: Time to chopping;		K: Factor of over crossing.			
Result: Passed.					

Test Report







No.: CTQC/ZJ-23.0043

Total 27 Page 26

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage wave



Test Report				No.: CTQC/ZJ-23. 0043 Total 27 Page 27	
4.17 Dry power-frequency voltage withstand test (Routine test)				Test date: Feb. 24, 2023	
Humidity: 38.0%; Ambient temperature: 10.9°C; Atmospheric pressure: 101.6kPa					
Applied position	Applied voltage(kV)		Frequency (Hz)	Duration (s)	Result
	Standard value	Applied value			
Terminals-earth	505	505	50	60	Passed
4.18 Tightness test at the flange (Routine test)				Test date: Feb. 24, 2023	
Applied pressure(MPa)	Duration(min)	Residual pressure(MPa)	Result		
0.4	15	0.4	No leakage and damage, passed.		
4.19 Measurement of partial discharge quantity (Routine test)				Test date: Feb. 24, 2023	
Humidity: 38.0%; Ambient temperature: 10.9°C; Atmospheric pressure: 101.6kPa					
Prestress voltage (kV)	Duration (s)	Measured voltage (kV)	Partial discharge level(pC)	Result	
505	60	252	<5	Passed	
		218.2	<5		
		152.8	<4		
Note: Background level was <4pC before and after test.					
4.20 Measurement of dielectric dissipation factor ($\tan \delta$) and capacitances at ambient temperature (Routine test)				Test date: Feb. 24, 2023	
Humidity: 38.0%; Ambient temperature: 10.9°C					
Applied voltage(kV)	Dielectric dissipation factor($\tan \delta$)	Capacitance(pF)	Result		
10	0.00296	571.0	Passed		
152.8	0.00367	571.5			
252	0.00392	571.6			
Note: $\tan \delta(252\text{kV}) - \tan \delta(152.8\text{kV}) = 0.00025 < 0.001$ (Standard value), passed.					

RATING PLATE AND OUTLINE PHOTOS


Rating plate:




Outline:



BUSHING DRAWINGS




B-B direction diagram



A-direction diagram

A向示意图




4-M16用于起吊和接地
4-M16 is used for lifting and grounding

放气孔位置
Location of vent hole

Technical parameters

1. Rated voltage: 252kV, rated voltage: 220kV
2. Rated current :1600A
3. 1min power frequency withstand voltage: 505kV
4. Lightning impulse withstand voltage: 1050kV
5. Dielectric loss tangent: $\leq 0.4\%$
6. PD: Um measured ≥ 10
7. Bending load: 4000N
8. Creepage distance: 8600mm
9. Operating ambient temperature: $+60^{\circ}\text{C} \sim -60^{\circ}\text{C}$

图纸验收专用章		QXBRP (G)WD-L-252/1600-4		Shandong Jitong high voltage electricity co., Ltd	
标记	处数	分区	更改文件号	签名	年月日
设计	张学明	2023.2.2	标准化		
审核	石孝刚	2023.2.2			
工艺					
批准	曹明波	2023.2.2			
阶段标记	重量	比例			
		1:18	Plastic paper transformer bushing outline		
共	张	第	张	Product number: PCB1920	



借 (通) 用
件 登 记

旧底图总号

底图总号

签 字

日 期

标 记

处 数 分 区

更 改 文 件 号

签 字

日 期

设 计

张 学 明

2023.2.2

标 准 化

校 核

石 孝 刚

2023.2.2

审 定

会 签

批 准

曹 明 波

2023.2.2

产品型号

铭牌 nameplate

316L

装 配 图 代 号 序 号

8QX.860.008G

图 样 标 记 重 量 比 例

0.030 1:1

共 张 第 张

Shandong Qixing High Voltage Electric Co. LTD 山东七星高压电气有限公司

CHPTL

中国大容量试验联盟(简称 CHPTL)是中国同类试验机构的唯一协作组织, 隶属于中国电工技术学会. 其主要目标是规范国家标准、行业标准及 IEC 标准在电力设备(交流 1000V 以上, 直流 1200V 以上)型式试验中的协调应用.

China High Power Testing liaison (CHPTL) is the only organization in China which is formed to promote and coordinate the application of IEC/GB standard as well as industry standards in power electrical equipment type test (AC above 1000V, DC above 1200V). CHPTL is under the leadership and management of China Electro-technical Society.

CHPTL 成员单位如下:

The members of CHPTL are as follows:

西安高压电器研究院有限责任公司(XIHARI)

Xi'an High Voltage Apparatus Research Institute Co., Ltd. (XIHARI)

中国电力科学研究院(CEPRI)

China Electrical Power Research Institute (CEPRI)

辽宁高压电器产品质量检测有限公司(AQTC)

Liaoning High Voltage Apparatus Quality Test Co., Ltd. (AQTC)

沈阳变压器研究院有限公司变压器实验室(STRI)

Shenyang Transformer Institute Co., Ltd Transformer Laboratory (STRI)

上海电气输配电试验中心有限公司(SETC)

Shanghai Electric Power Transmission & Distribution Testing Center Co., Ltd. (SETC)

电力工业无功补偿成套装置质量检验测试中心(PRCIQTC)

Power Industry Reactive Compensation Equipment Quality Inspection & Test Center(PRCIQTC)

CHPTL 作为一个协作组织, 本身并不出具型式试验报告. 每一个 CHPTL 成员对其出具的型式试验报告的有效性和内容负责.

CHPTL as a collaboration does not itself issue test reports. Each CHPTL member issuing a test report is responsible for the validity and contents of that report.