



230008349512



中国认可
国际互认
检测
TESTING
CNAS L0681



CHPTL

TEST REPORT

No : CTQC/ZJ-23. 0585

Test object name: Adhesive paper capacitive transformer
bushing

Test object type: QXBRPW-550/4000-4

Entrusted by: Shandong Qixing High Voltage Electric
CO.,Ltd.

Manufacturer: Shandong Qixing High Voltage Electric
CO.,Ltd.

Kind of testing: Type Tests



SHENYANG TRANSFORMER RESEARCH INSTITUTE CO., LTD.

CHINA NATIONAL TRANSFORMER QUALITY DETECTION AND TESTING CENTER

CX-F-01	Test Report	No: CTQC/ZJ-23.0585 Total 32 page 1
---------	-------------	--

CONTENTS

	Page
1. Testing report cover	
2. Contents.....	1
3. Signing and issuing.....	2
4. Test results.....	3~5
5. Test object parameters.....	6
6. Sample condition description.....	6
7. Standards.....	6
8. Test items and conclusions.....	7~32
9. Annex 1: Rating plate and outline photos(Total page 1)	
10. Annex 2: Bushing drawings(Total pages 2)	

Shenyang Transformer Research Institute Co., Ltd.

China National Transformer Quality Detection And Testing Center

Test Report

No: CTQC/ZJ-23.0585


Total 32 page 2


Test object name	Adhesive paper capacitive transformer bushing	Test object type	QXBRPW-550/4000-4
		Brand	/
Entrusted by	Shandong Qixing High Voltage Electric CO.,Ltd.	Kind of testing	Type test
Manufacturer	Shandong Qixing High Voltage Electric CO.,Ltd.	Sampling date	/
		Test date	Jul.18, 2023 ~Jul.22, 2023
Address	No.1228,Pengcheng Industrial Park, Pingli Road, Xiazhuang Town, Gaomi City, Weifang City, Shandong Province	Serial No	2307PB001
Standards	IEC60137: 2017 GB/T4109-2022 Technical contract	Test items	Routine test Type test
Results	<p>The test results of routine tests, type tests of QXBRPW-550/4000-4 are in accordance with standards and technical contract. The sample passed the above tests.</p> <p style="text-align: right;">Signing and issuing date: 2023.08.01</p>		
Note			

Approved by: Lv Xiangpeng

Checked by: Du Jiansong

Compiled by: Song Jialin





- Statement :
1. Testing report is invalid without test special seal.
 2. Testing report is invalid without compiler, checker and approver's signature.
 3. Please inform CTQC in time after received the testing report if you have some disagreement to the testing report..
 4. Testing or witnessing only apply to sample.
 5. Copying testing certificate or testing report is forbidden without written permission from CTQC(except for copying all the testing report).

Test Report		No: CTQC/ZJ-23. 0585		
		Total 32 page 3		
Test results				
No	Test items	Specified values	Measured values	Conclusions
		Standards(Technical contract)		
1	Measurement of dielectric dissipation factor ($\tan\delta$) and capacitances at ambient temperature (Before type test)	Applied voltage(kV):2~20 $\tan\delta: \leq 0.007$ Providing capacitance of the sample (pF)	10 0.00335 754.8	Passed
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ $\tan\delta: \leq 0.007$ Providing capacitance of the sample (pF)	333.4 0.00337 755.4	
		Applied voltage(kV): U_m $\tan\delta: \leq 0.007$ Providing capacitance of the sample (pF)	550 0.00340 755.5	
2	Measurement of partial discharge quantity (Before type test)	Applied voltage(kV): U_m Partial discharge level(pC): ≤ 10	550 <4	Passed
		Applied voltage(kV): $1.5U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 10	476.3 <4	
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 5	333.4 <4	
3	Dry lightning impulse voltage withstand test (Type test)	Full wave voltage: Positive polarity(kV): 1686(Corrected value) $\pm 3\%$ Negative polarity(kV): 1855.5(Corrected value) $\pm 3\%$ 15 positive and 15 negative polarity full wave impulses Chopped wave voltage(kV): 2040.8(Corrected value) $\pm 3\%$ 5 negative polarity chopped wave impulses	1657.41~1729.63 1848.05~1887.09 Each 15 times 2032.79~2099.35 5 times	Passed
4	Dry switch impulse voltage withstand test (Type test)	Full wave voltage: Negative polarity(kV): 1432.3(Corrected value) $\pm 3\%$ 15 negative polarity	1399.64~1445.34 15 times	Passed
5	Wet switch impulse voltage withstand test (Type test)	Full wave voltage: Positive polarity(kV): 1281.8(Corrected value) $\pm 3\%$ Negative polarity(kV): 1300 $\pm 3\%$ 15 positive and 15 negative polarity	1298.07~1307.18 1268.28~1278.41 Each 15 times	Passed
6	Dry power-frequency voltage withstand test (Type test)	Applied voltage(kV): 752.1(Corrected value) Duration(s): 60	752.1 60	Passed

Test Report			No: CTQC/ZJ-23. 0585	
			Total 32 page 4	
No	Test items	Specified values	Measured values	Conclusions
		Standards(Technical contract)		
7	Long-duration power-frequency voltage withstand test (ACLD) (Type test)	U ₁ =U _m (kV) Duration(s): 60	550 60	Passed
		U ₂ =1.5U _m /√3 (kV) Duration(min): 60 Partial discharge level (pC): ≤10	476.3 60 <4	
		1.1U _m /√3 (kV) Duration(min): 5 Partial discharge level (pC): ≤5	349.3 5 <4	
8	Radio interference voltage test (Type test)	Applied voltage (kV) : 1.1U _m /√3 Duration (min) : 5 Radio interference level(μ V): ≤500	349.3 5 282	Passed
9	Thermal stability test (Type test)	Oil temperature (°C) : 90±2 Applied voltage(kV): 0.8 U _m	90 440	Passed
10	Temperature-rise test (Type test)	Temperature limit(°C):120 Temperature-rise limit(K): 75	68.1~93.9 38.7~64.5	Passed
11	Verification of thermal short-time current withstand (Type test)	Thermal short-time current (kA) : 25I _r Duration(s):2 Final temperature (°C):≤180	100 2 118.4	Passed
12	Cantilever load withstand test (Type test)	Applied load(N): 5000 Duration(s): 60 Successfully repeat check items	5046 60 Passed	Passed
13	Visual inspection and dimensions check (Type test)	According to standard	See 4.13	Passed
14	Measurement of partial discharge quantity (After type test)	Applied voltage(kV):U _m Partial discharge level(pC):≤10	550 <4	Passed
		Applied voltage(kV):1.5U _m /√3 Partial discharge level(pC):≤10	476.3 <4	
		Applied voltage(kV):1.05U _m /√3 Partial discharge level(pC):≤5	333.4 <4	

Test Report			No: CTQC/ZJ-23.0585	
			Total 32 page 5	
No	Test items	Specified values	Measured values	Conclusions
		Standards(Technical contract)		
15	Measurement of dielectric dissipation factor (tanδ) and capacitances at ambient temperature (After type test)	Applied voltage(kV):2~20 tanδ: ≤0.007 Providing capacitance of the sample (pF)	10.0 0.00334 754.6	Passed
		Applied voltage(kV):1.05U _m /√3 tanδ: ≤0.007 Providing capacitance of the sample(pF)	333.4 0.00335 755.2	
		Applied voltage(kV):U _m tanδ: ≤0.007 Providing capacitance of the sample(pF)	550 0.00335 755.2	
16	Test of tap insulation (Routine test)	Dry power-frequency voltage withstand test on the tap: Applied voltage(kV): ≥2 Duration(s): 60	 2 60	Passed
		Measurement of dielectric dissipation factor (tanδ) and capacitances at ambient temperature on the tap: Applied voltage(kV): ≥1 tanδ: ≤0.05 Capacitance(pF): ≤10000	 2 0.00618 1198	
17	Dry lightning impulse voltage withstand test (Routine test)	Negative polarity(kV):1758.8 ± 3% 3 negative polarity Chopped wave voltage(kV): 1926.3 ± 3% 2 negative polarity	1773.33~1806.00 3 times 1902.48~1922.71 2 times	Passed
18	Dry power-frequency voltage withstand test (Routine test)	Applied voltage(kV):750 Duration (s) : 60	750 60	Passed
19	Measurement of partial discharge quantity (Routine test)	Applied voltage(kV): U _m Partial discharge level(pC): ≤10	252 <3	Passed
		Applied voltage(kV): 1.5U _m /√3 Partial discharge level(pC):≤10	476.3 <3	
		Applied voltage(kV):1.05U _m /√3 Partial discharge level(pC):≤5	333.4 <2	

Test Report			No: CTQC/ZJ-23.0585 Total 32 page 6	
No	Test items	Specified values	Measured values	Conclusions
		Standards(Technical contract)		
20	Measurement of dielectric dissipation factor ($\tan\delta$) and capacitances at ambient temperature (Routine test)	Applied voltage(kV):2~20 $\tan\delta: \leq 0.007$ Providing capacitance of the sample(pF)	10.0 0.00335 754.8	Passed
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ $\tan\delta: \leq 0.007$ Providing capacitance of the sample (pF)	333.4 0.00336 755.4	
		Applied voltage(kV): U_m $\tan\delta: \leq 0.007$ Providing capacitance of the sample (pF)	550 0.00336 755.5	
21	Tightness test at the flange (Routine test)	Applied medium Applied pressure(MPa): 0.40 ± 0.01 Durations(min): 15 No oil leakage and damage	SF ₆ 0.4 15 No oil leakage and damage	Passed
22	Visual inspection and dimensions check (Routine test)	According to standard	See 4.13	Passed

Note: 1. All the tests were field tests;
2. Tested in Shandong Qixing High Voltage Electric Co., Ltd. laboratory.

Test Report		No: CTQC/ZJ-23. 0585 Total 32 page 7
<p>1. Test object parameters</p> <p>Highest voltage for equipment(kV): 550</p> <p>Rated phase-to-earth voltage(kV): $550/\sqrt{3}$</p> <p>Rated current(A): 4000</p> <p>Rated frequency(Hz): 50</p> <p>Altitude(m): ≤ 1000</p> <p>Temperature class of insulation: E</p> <p>Test tap(measured tap, $\tan\delta$): With</p> <p>Insulation type of bushing: Adhesive paper</p> <p>Rated voltage of tap(Tap of electric potential, tap of capacitance) (kV): /</p> <p>2. Sample condition description</p> <p>Sample exterior construction and major dimensions(length, diameter) are in compliance with outline drawings.</p> <p>Measured values: Length is 7672 mm, external diameter is $\Phi 800$ mm.</p>		
Rating plate	Outline dimensions	
PCBT55-1228	8QX.860.009G	
<p>Rating plate and outline drawings are in testing report annex, other drawings should be conserved by enterprise after affirming by CTQC.</p> <p>The form, performance data, specifications of sample ra</p> <p>3. Standards</p> <p>IEC60137: 2017, GB/T4109-2022 Insulated bushings for alternating voltage above 1000V</p> <p>Technical contract</p>		

Test Report

No: CTQC/ZJ-23.0585

Total 32 page 8

4. Test items and conclusions

4.1 Measurement of dielectric dissipation factor ($\tan \delta$) and capacitances at ambient temperature (Before type test)

Test date: Jul.18,2023

Humidity: 46.0%; Ambient temperature: 31.1°C

Applied voltage (kV)	Dielectric dissipation factor ($\tan \delta$)	Capacitance(pF)	Result
10.0	0.00335	754.8	Passed
333.4	0.00337	755.4	
550	0.00340	755.5	

Note: $\tan \delta(550\text{kV}) - \tan \delta(333.4\text{kV}) = 0.00003 < 0.001$ (Standard value), passed.

4.2 Measurement of partial discharge quantity (Before type test)

Test date: Jul.18,2023

Humidity: 46.0%; Ambient temperature: 31.1°C; Atmospheric pressure: 101.2kPa

Prestress voltage (kV)	Duration (s)	Measured voltage (kV)	Partial discharge level(pC)	Result
750	60	550	<4	Passed
		476.3	<4	
		333.4	<4	

Note: Background level is <4pC before and after test.

Test Report

No: CTQC/ZJ-23.0585

Total 32 page 9

4.3 Dry lightning impulse voltage withstand test (Type test)

Test date: Jul.18,2023

Test atmospheric conditions:

Ambient temperature: 31.2°C; Humidity: 46.0%; Atmospheric pressure: 101.2kPa

Full wave rated withstand voltage: positive polarity: 1686.6kV(Corrected value) 15 positive polarity impulses;

Negative polarity: 1855.5kV(Corrected value) 15 negative polarity impulses;

Chopped wave rated withstand voltage: 2040.8 kV(Corrected value) 5 negative polarity impulses.

Test sequence:

One positive polarity reference voltage full wave impulse;

Fifteen positive polarity rated voltage full wave impulse;

One negative polarity reference voltage full wave impulse;

One negative polarity rated voltage full wave impulse;

Five negative polarity rated chopped wave impulse;

Fourteen negative polarity rated voltage full wave impulse.

Test oscillogram records:

 T_1 : Front time; T_2 : Time to half value; U_{pk} : Peak voltage; T_c : Time to chopping; Q_z : Factor of over crossing

Result: Passed.

Test Report









No: CTQC/ZJ-23.0585

Total 32 page 10

Tested terminal: To earth

Test polarity: Positive

CH1: Voltage records



Test Report









No : CTQC/ZJ-23. 0585

Total 32 page 11

Tested terminal: To earth

Test polarity: Positive

CH1: Voltage records



Test Report








No: CTQC/ZJ-23. 0585

Total 32 page 12

Tested terminal: To earth

CH1.Voltage records

Test polarity: Negative



Test Report









No: CTQC/ZJ-23.0585

Total 32 page 13

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage records



Test Report







No : CTQC/ZJ-23. 0585

Total 32 page 14

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage records



Test Report

No: CTQC/ZJ-23.0585

Total 32 page 15

4.4 Dry switch impulse voltage withstand test (Type test)

Test date: Jul.18,2023

Test atmospheric conditions: Humidity: 43.0%; Ambient temperature: 32.3°C; Atmospheric pressure: 101.8kPa.

Rated switch impulse withstand voltage:

Negative: 1432.3kV (Corrected value)

Fifteen positive rated full wave switch impulses;

Test sequence:

One negative reference full wave impulse;

Fifteen negative rated full wave impulses;

Test oscillogram records:

Tp: Front time;

T2: Time to half value;

Upk: Peak voltage;

Result: Passed.

Test Report









No: CTQC/ZJ-23.0585

Total 32 page 16

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage records



Test Report









No: CTQC/ZJ-23.0585

Total 32 page 17

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage records



Test Report

No: CTQC/ZJ-23.0585

Total 32 page 18

4.5 Wet switch impulse voltage withstand test (Type test)

Test date: Jul.18,2023

Test atmospheric conditions: Humidity: 45.0%; Ambient temperature: 33.4°C; Atmospheric pressure: 100.6kPa.

The conductivity of collected water is 100.3 $\mu\text{S}/\text{cm}$ at 20°C.

Vertical component 1.4mm/min, horizontal component 1.3mm/min.

Rated switch impulse withstand voltage:

Positive: 1281.8kV (Corrected value)

Negative: 1300kV

Fifteen positive and negative rated full wave switch impulses;

Test sequence:

One positive polarity reference voltage full wave impulse;

Fifteen positive polarity rated voltage full wave impulses;

One negative polarity reference voltage full wave impulse;

Fifteen negative polarity rated voltage full wave impulses;

Test oscillogram records:

Tp: Front time;

T2: Time to half value;

U_{pk}: Peak voltage;









Result: Passed.

Test Report

No: CTQC/ZJ-23.0585

Total 32 page 19

Tested terminal: To earth Test polarity: Positive CH1: Voltage records











Test Report

No: CTQC/ZJ-23.0585

Total 32 page 20

Tested terminal: To earth Test polarity: Positive CH1: Voltage records











Test Report

No: CTQC/ZJ-23.0585

Total 32 page 21

Tested terminal: To earth Test polarity: Negative CH1: Voltage records











Test Report

No: CTQC/ZJ-23.0585

Total 32 page 22

Tested terminal: To earth Test polarity: Negative CH1: Voltage records



Test Report	No: CTQC/ZJ-23. 0585 Total 32 page 23
--------------------	--

4.6 Dry power-frequency voltage withstand test (Type test)

Test date: Jul.19,2023

Humidity:60.0%; Ambient temperature: 29.7°C; Atmospheric pressure: 101.0kPa

Position	Applied voltage(kV)			Frequency (Hz)	Duration (s)	Result
	Standard value	Atmospheric corrected value	Applied value			
Terminal-earth	750	752.1	752.1	50	60	Passed

4.7 Long-duration power-frequency withstand voltage test (ACLD) (Type test)

Test date: Jul.19,2023

Ambient temperature: 29.7°C

Applied voltage		Duration(min)	Partial discharge level(pC)
Multiple	Phase-earth(kV)		
$1.1U_m/\sqrt{3}$	349.3	5	<4
$U_2=1.5U_m/\sqrt{3}$	476.3	5	<4
$U_1=U_m$	550	1	/
$U_2=1.5U_m/\sqrt{3}$	476.3	5	<4
		10	<4
		15	<4
		20	<4
		25	<4
		32	<4
		35	<4
		40	<4
		45	<4
		50	<4
55	<4		
60	<4		
$1.1U_m/\sqrt{3}$	349.3	5	<4

Note: $U_m=550kV$;

Background level is <4pC before and after test.

Result: Passed.

<h2 style="margin: 0;">Test Report</h2>	No: CTQC/ZJ-23.0585 Total 32 page 24
---	---


4.8 Radio interference voltage test (Type test)

Test date: Jul.19,2023

Humidity:60.0%; Ambient temperature: 29.7°C; Atmospheric pressure: 101.0kPa

Measured frequency (MHz)	Attenuation factor of measurement circuit (dB)	Attenuation factor of resistance network (dB)	Measured voltage (kV)	Measured voltage (kV)	Radio interference reading B _m (dB)	Radio interference level (μV)
1.0	11	22	349.3	5	16	282
			317.5		16	282
			285.8		16	282
			254.0		16	282
			222.3		16	282
			190.5		16	282
			158.8		16	282
			127.0		16	282
			95.3		16	282

Result: Passed.



Test Report

No: CTQC/ZJ-23. 0585

Total 32 page 25

4.9 Thermal stability test (Type test)

Test date:Jul.21,2023

Duration(h)	Applied voltage (kV)	$\tan\delta$	Cx (pF)	Oil temperature (°C)	Ambient temperature(°C)
0	440	0.00336	755.5	89.1	30.5
0.5	440	0.00336	755.5	89.4	30.5
1.0	440	0.00336	755.6	90.2	31.5
1.5	440	0.00337	755.6	90.2	31.8
2.0	440	0.00337	755.7	90.4	32.4
2.5	440	0.00337	755.7	90.4	32.8
3.0	440	0.00338	755.7	90.4	33.4
3.5	440	0.00338	755.8	90.5	33.8
4.0	440	0.00339	755.8	90.5	34.0
4.5	440	0.00339	755.8	90.5	34.0
5.0	440	0.00339	755.8	90.5	34.1

Result: Passed.

Test Report	No : CTQC/ZJ-23. 0585 Total 32 page 26
--------------------	---

4.10 Temperature-rise test (Type test)

Test date: Jul.21,2023


Specified current was 4000A, injected current was 4000A during test, the test duration was 8h, stability duration was 1h.

Temperature-rise calculated value

No.	Measurement position	Temperature (°C)	Temperature-rise(K)	Oil temperature (°C)	Ambient temperature (°C)	Result
1	Terminal in the air	81.2	51.8	29.4	91.2	Passed
2	Firmness of terminal in the air	78.6	49.2			
3	Flange	68.1	38.7			
4	Firmness of terminal in the oil	91.9	62.5			
5	Terminal in the oil	93.9	64.5			

The measurement position drawing is shown in Page 27.

Schematic diagram of measured point of temperature rise



- 1. Terminal in the air 2. Firmness of terminal in the air 3. Conducting rod top part 4. Conducting rod middle part
- 5. Flange 6. Transformer oil

Test Report		No: CTQC/ZJ-23.0585 Total 32 page 28
4.11 Verification of thermal short-time current withstand (Verify by the calculation) (Type test)		
Test date: Jul.21,2023		
The standard value of thermal short-time current of bushing $I_{th}=100\text{kA}$, duration $t_{th}=2\text{s}$. According to calculation final temperature of the conductor $\theta_f=118.4^\circ\text{C}$. If $\theta_f \leq 180^\circ\text{C}$, it was considered that the bushing could withstand the standard value I_{th} of thermal short-time current.		
Sample parameters		
Conductor material of sample	Aluminium	
Conductor resistivity $\rho(\mu\Omega\cdot\text{cm})$	2.83	
Total cross section area $S_t(\text{cm}^2)$	78.50	
Measured temperature rise of the bushing (K)	64.5	
Rated current $I_r(\text{A})$	4000	
Standard value of rated thermal short-time current $I_{th}(\text{kA})$	100	
Rated duration $t_{th}(\text{s})$	2	
$\theta_0(^\circ\text{C})$	104.5	
Current penetration depth $d(\text{cm})$	1.198	
Diameter of the conductor $D(\text{cm})$	10.0	
$\alpha[(\text{K/s})/(\text{kA}/\text{cm}^2)^2]$	1.8	
Equivalent cross section area considering the skin effect $S_e(\text{cm}^2)$	33.11	
Verify by the calculation:		
$\theta_f = \theta_0 + \alpha \frac{I_{th}^2}{S_t \times S_e} \times t_{th} = 118.4^\circ\text{C}$		
Result: Passed.		

Test Report

No: CTQC/ZJ-23.0585

Total 32 page 29

4.12 Cantilever load withstand test (Type test)

Test date: Jul.22,2023

Load direction	Applied position	Standard value		Applied value		Result
		Load (N)	Duration(s)	Load (N)	Duration(s)	
Vertical	Terminal	5000	60	5046	60	No damage, distortion, passed

4.13 Visual inspection and dimensions check (Type test)

Test date: Jul.18,2023

It has smooth surface, no cracks. Dimensional check is accordance with the drawing requirement.

Drawing values (mm): 7680±30 1800±20 4700±20 Ø800

Measured values (mm): 7672 1795 4696 Ø800

Arcing distance (mm): 4750

Creepage (mm): 20680

Result: Passed.

4.14 Measurement of partial discharge quantity (After type test)

Test date: Jul.22,2023

Humidity: 72.0%; Ambient temperature: 27.7°C; Atmospheric pressure: 100.5kPa

Prestress voltage (kV)	Duration(s)	Measured voltage (kV)	Partial discharge level (pC)	Result
750	60	550	<4	Passed
		476.3	<4	
		333.4	<4	

Note: Background level is <4pC before and after test.

4.15 Measurement of dielectric dissipation factor ($\tan \delta$) and capacitances at ambient temperature (After type test)

Test date: Jul.22,2023

Humidity: 72.0%; Ambient temperature: 27.7°C

Applied voltage (kV)	Dielectric dissipation factor ($\tan \delta$)	Capacitance (pF)	Result
10	0.00334	754.6	Passed
333.4	0.00335	755.2	
550	0.00335	755.2	

Note: $\tan \delta(550\text{kV}) - \tan \delta(333.4\text{kV}) = 0.00003 < 0.001$ (Standard value), passed.

Test Report				No: CTQC/ZJ-23.0585
				Total 32 page 30
4.16 Tests of tap insulation (Routine test)				Test date: Jul.22,2023
Power-frequency voltage withstand test on the tap				
Humidity: 72.0%; Ambient temperature: 27.7°C; Atmospheric pressure: 100.5kPa				
Applied position	Applied voltage(kV)	Frequency(Hz)	Duration(s)	Result
Tap—earth	2	50	60	Passed
Measurement of dielectric dissipation factor (tanδ) and capacitances at ambient temperature on the tap				
Humidity: 72.0%; Ambient temperature: 27.7°C				
Applied voltage(kV)	Dielectric dissipation factor(tanδ)	Capacitance(pF)	Result	
2	0.00618	1198	Passed	
4.17 Dry lightning impulse voltage withstand test (Routine test)				Test date: Jul.22,2023
Test atmospheric conditions				
Humidity: 72.0%; Ambient temperature: 27.7°C; Atmospheric pressure: 100.5kPa				
Full wave rated withstand voltage: negative polarity: 1758.8kV;			3 negative polarity	
Chopped wave rated withstand voltage: negative polarity: 1926.3kV;			2 negative polarity	
Test sequence				
One negative reference full wave impulse;				
One negative rated full wave impulses;				
Two negative rated chopped wave impulses;				
Two negative rated full wave impulses.				
Test records:				
T1: Front time; T2: Time to half value; Upk: Peak voltage;				
Tc: Time to chopping; Qz: Factor of over crossing.				
Result: Passed.				

Test Report







No: CTQC/ZJ-23. 0585

Total 32 page 31

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage wave



Test Report				No: CTQC/ZJ-23.0585 Total 32 page 32		
4.18 Dry power-frequency voltage withstand test (Routine test)						
Test date: Jul.22,2023						
Humidity: 72.0%; Ambient temperature: 27.7°C; Atmospheric pressure: 100.5kPa						
Position	Applied voltage(kV)			Frequency (Hz)	Duration (s)	Result
	Standard value	Atmospheric corrected	Applied value			
Terminal—earth	750	/	750	50	60	Passed
4.19 Measurement of partial discharge quantity (Routine test)						
Test date: Jul.22,2023						
Humidity: 72.0%; Ambient temperature: 27.7°C; Atmospheric pressure: 100.5kPa						
Prestress voltage (kV)	Duration(s)	Measured voltage(kV)	Partial discharge level(pC)	Result		
750	60	550	<4	Passed		
		476.3	<4			
		333.4	<4			
Note: Background level is <4pC before and after test.						
4.20 Measurement of dielectric dissipation factor ($\tan\delta$) and capacitances at ambient temperature (Routine test)						
Test date: Jul.22,2023						
Humidity: 72.0%; Ambient temperature: 27.7°C; Atmospheric pressure: 100.5kPa						
Applied voltage (kV)	Dielectric dissipation factor ($\tan\delta$)	Capacitance(pF)	Result			
10	0.00335	754.8	Passed			
333.4	0.00336	755.4				
550	0.00336	755.5				
Note: Background level is <4pC before and after test.						
4.21 Tightness test at the flange (Routine test)						
Test date: Jul.22,2023						
Applied medium	Applied pressure(MPa)	Duration(h)	Residual pressure(MPa)	Result		
SF6	0.4	15	0.4	No leakage or damage, passed		
4.22 Visual inspection and dimensions check (Routine test)						
Test date: Jul.22,2023						
It has smooth surface, no cracks. Dimensional check is accordance with the drawing requirement. Dimensional inspection see 4.2.						
Result: Passed.						

RATING PLATE AND OUTLINE PHOTOS


Rating plate:



Outline:





BUSHING DRAWINGS



借 (通) 用
件 登 记

旧底图总号						产品型号	装配图代号	序号	
底图总号						铭牌nameplate	8QX.860.009G		
签字							图样标记	重量	比例
日期	标记	处数	分区	更改文件号	签字	日期		0.030	1:1
档案员	日期	设计	张学明	2023.7.5	标准化		共 张	第 张	
		审核	石孝刚	2023.7.5	审 定		Shandong Qixing High Voltage Electric Co. LTD山东七星高压电气有限公司		
		会签			批准	曹明波	316L		
						2023.7.5			



Lightning strikes at 1675kV

Power frequency withstand voltage 750kV/1min

Partial discharge UmkV<<10pC



Dielectric loss factor <0.4%

Pollution Grade IV /31mm/kV(Creepage distance ≥20460mm)

Altitude: <1000m

Bending load: ≥5kN

Other requirements comply with the latest GB/T4109 and IEC60137



标记	处数	分区	更改文件号	签名	年、月、日
设计	Zhang	Wang	2023.5.10	标准化	
审核	Shi	Langang	2023.5.10		
工艺					
批准	cao	Wang	2023.5.10		

QYBRPW-550/4000-4		
阶段标记	重量	比例
		1:10
共	张	第
5	张	张

Shandong High Voltage Electric Co., Ltd
Adhesive paper capacitive transformer bushing
Picture No.: PCB155-1228
Product number: PCB1228

全套
Confirm
OKA.605.103

1 2 3 4 5 6

CHPTL

中国大容量试验联盟（简称 CHPTL）是中国同类试验机构的唯一协作组织，隶属于中国电工技术学会。其主要目标是规范国家标准、行业标准及 IEC 标准在电力设备(交流 1000V 以上，直流 1200V 以上)型式试验中的协调应用。

China High Power Testing liaison (CHPTL) is the only organization in China which is formed to promote and coordinate the application of IEC/GB standard as well as industry standards in power electrical equipment type test (AC above 1000V, DC above 1200V). CHPTL is under the leadership and management of China Electro-technical Society.

CHPTL 成员单位如下：

The members of CHPTL are as follows:

西安高压电器研究院有限责任公司(XIHARI)

Xi'an High Voltage Apparatus Research Institute Co., Ltd. (XIHARI)

中国电力科学研究院(CEPRI)

China Electrical Power Research Institute (CEPRI)

辽宁高压电器产品质量检测有限公司(AQTC)

Liaoning High Voltage Apparatus Quality Test Co., Ltd. (AQTC)

沈阳变压器研究院有限公司变压器实验室(STRI)

Shenyang Transformer Institute Co., Ltd Transformer Laboratory (STRI)

上海电气输配电试验中心有限公司(SETC)

Shanghai Electric Power Transmission & Distribution Testing Center Co., Ltd. (SETC)

电力工业无功补偿成套装置质量检验测试中心(PRCIQTC)

Power Industry Reactive Compensation Equipment Quality Inspection & Test Center(PRCIQTC)

CHPTL 作为一个协作组织，本身并不出具型式试验报告。每一个 CHPTL 成员对其出具的型式试验报告的有效性和内容负责。

CHPTL as a collaboration does not itself issue test reports. Each CHPTL member issuing a test report is responsible for the validity and contents of