



250008343110



中国认可
国际互认
检测
TESTING
CNAS L0681



CHPTL

TEST REPORT

No : CTQC/ZJ-25. 0095

Test object name: Resin-impregnated paper capacitive transformer bushing

Test object type: QXFBRPWD-L-72.5/1250-4

Entrusted by: Shandong Qixing High voltage Electric CO., Ltd

Manufacturer: Shandong Qixing High voltage Electric CO., Ltd

Kind of testing: Type tests

SHENYANG TRANSFORMER RESEARCH INSTITUTE CO., LTD.

CHINA NATIONAL TRANSFORMER QUALITY DETECTION AND TESTING CENTER



CX-F-01	Test Report	No: CTQC/ZJ-25.0095 Total 20 Page 1
---------	-------------	--

CONTENTS

	Page
1. Test report cover	
2. Contents.....	1
3. Signing and issuing.....	2
4. Test results.....	3~5
5. Test object parameters.....	6
6. Sample condition description.....	6
7. Standards	6
8. Test items and conclusions.....	7~20
9. Annex1: Rating plate and outline photo(Total page 1)	
10. Annex 2: Bushing drawings(Total pages 2)	

Shenyang Transformer Research Institute Co., Ltd.

China National Transformer Quality Detection And Testing Center

Test Report

No: CTQC/ZJ-25.0095

Total 20 Page 2

Test object name	Resin-impregnated paper capacitive transformer bushing	Test object type	QXFBRPWD-L-72.5/1250-4
		Brand	/
Entrusted by	Shandong Qixing High Voltage Electric CO., Ltd.	Kind of testing	Type test
Manufacturer	Shandong Qixing High Voltage Electric CO., Ltd.	Sampling date	/
		Test date	Feb. 10, 2025~Feb. 17, 2025
Address	No.1228,Pengcheng Industrial Park, Pingli Road, Xiazhuang Town, Gaomi City, Weifang City, Shandong Province	Serial No	2502PB003
Standards	IEC60137: 2017 GB/T4109-2022 Technical contract	Test items	Routine tests Type tests
Results	The test results of routine tests, type tests of QXFBRPWD-L-72.5/1250-4 are in accordance with standards and technical contract. The sample passed the above tests.		
Note	Signing and issuing date: 2025.02.25		

Approved by: Lv Xiangpeng

Checked by: Du Jiansong

Compiled by: Zhang Yan

- Statement:
1. Testing report is invalid without test special seal.
 2. Testing report is invalid without compiler, checker and approver's signature.
 3. Please inform CTQC in time after received the testing report if you have some disagreement to the testing report.
 4. Testing or witnessing only apply to sample.
 5. Copying testing certificate or testing report is forbidden without written permission from CTQC (except for copying all the testing report).

Test Report

№: CTQC/ZJ-25.0095

Total 20 Page 3

Test results

№	Test items	Specified values	Measured values	Conclusions
		Standards (Technical contract)		
1	Measurement of dielectric dissipation factor ($\tan\delta$) and capacitances at ambient temperature (Before type test)	Applied voltage(kV): 2~20 $\tan\delta$: ≤ 0.004 Providing capacitance of the sample(pF)	10 0.00303 413.1	Passed
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ $\tan\delta$: ≤ 0.004 Providing capacitance of the sample(pF)	44 0.00308 413.4	
		Applied voltage(kV): U_m $\tan\delta$: ≤ 0.004 Providing capacitance of the sample(pF)	72.5 0.00310 413.5	
2	Measurement of partial discharge quantity (Before type test)	Applied voltage(kV): U_m Partial discharge level(pC): ≤ 10	72.5 <4	Passed
		Applied voltage(kV): $1.5U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 10	62.8 <4	
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 5	44 <4	
3	Dry lightning impulse voltage withstand test (Type test)	Full wave voltage Positive polarity(kV): 317.2(Corrected value) $\pm 3\%$ Negative polarity(kV): 357.5 $\pm 3\%$ 15 positive and 15 negative polarity Chopped wave voltage(kV): 393.3 $\pm 3\%$ 5 negative polarity	318.57~323.33 354.48~358.93 Each 15 times 392.95~396.77 5 times	Passed
4	Wet power-frequency voltage withstand test (Type test)	Applied voltage(kV): 140.8(Corrected value) Duration(s): 60	140.8 60	Passed
5	Long-duration power-frequency voltage withstand test(ACL D) (Type test)	$U_1=U_m$ (kV) Duration(s): 60	72.5 60	Passed
		$U_2=1.5U_m/\sqrt{3}$ (kV) Duration(min): 60 Partial discharge level(pC): ≤ 10	62.8 60 <4	
		$1.1U_m/\sqrt{3}$ (kV) Duration(min): 5 Partial discharge level(pC): ≤ 5	46.1 5 <4	
6	Temperature rise test (Type test)	Temperature limit($^{\circ}$ C): 105/120 Temperature rise limit(K): 75/90	See 4.6	Passed
7	Verification of thermal short-time current withstand (Type test)	Thermal short-time current(kA): $25I_r$ Duration(s): 2	31.25 2	Passed
		Final temperature of the conductor($^{\circ}$ C): ≤ 180	146.3	

Test Report			№: CTQC/ZJ-25. 0095 Total 20 Page 4	
№	Test items	Specified values	Measured values	Conclusions
		Standards (Technical contract)		
8	Cantilever load withstand test (Type test)	Applied load(N): 4000 Duration(s): 60 Successfully repeat check items	4028 60 Passed	Passed
9	Visual inspection and dimensions check (Routine test)	According to standard	See 4.9	Passed
10	Measurement of partial discharge quantity (After type test)	Applied voltage(kV): U_m Partial discharge level(pC): ≤ 10	72.5 <4	Passed
		Applied voltage(kV): $1.5U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 10	62.8 <4	
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 5	44 <4	
11	Measurement of dielectric dissipation factor ($\tan\delta$) and capacitances at ambient temperature (After type test)	Applied voltage(kV): 2~20 $\tan\delta: \leq 0.004$ Providing capacitance of the sample(pF)	10 0.00300 413.3	Passed
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ $\tan\delta: \leq 0.004$ Providing capacitance of the sample(pF)	44 0.00301 413.5	
		Applied voltage(kV): U_m $\tan\delta: \leq 0.004$ Providing capacitance of the sample(pF)	72.5 0.00301 413.5	
12	Tests of tap insulation (Routine test, special test)	Dry power-frequency voltage withstand test: Applied voltage(kV): 3 Duration(s): 60	3 60	Passed
		Measurement of dielectric dissipation factor ($\tan\delta$) and capacitances: Applied voltage(kV): ≥ 1 $\tan\delta: \leq 0.05$ Capacitance(pF) : ≤ 10000	3 0.00502 194.0	
13	Dry lightning impulse voltage withstand test (Routine test)	Negative polarity(kV): 341.3 $\pm 3\%$ 3 negative polarity Chopped wave voltage(kV): 373.8 $\pm 3\%$ 2 negative polarity	342.7~348.8 3 times 371.58~376.84 2 times	Passed
14	Dry power-frequency voltage withstand test (Routine test)	Applied voltage(kV): 155 Duration(s): 60	155 60	Passed
15	Measurement of partial discharge quantity (Routine test)	Applied voltage(kV): U_m Partial discharge level(pC): ≤ 10	72.5 <4	Passed
		Applied voltage(kV): $1.5U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 10	62.8 <4	

Test Report			№: CTQC/ZJ-25. 0095 Total 20 Page 5	
№	Test items	Specified values	Measured values	Conclusions
		Standards (Technical contract)		
15	Measurement of partial discharge quantity (Routine test)	Applied voltage(kV): $1.05U_m/\sqrt{3}$ Partial discharge level(pC): ≤ 5	44 <4	Passed
16	Measurement of dielectric dissipation factor ($\tan\delta$) and capacitances at ambient temperature (Routine test)	Applied voltage(kV): 2~20 $\tan\delta: \leq 0.004$ Providing capacitance of the sample(pF)	10 0.00299 413.5	Passed
		Applied voltage(kV): $1.05U_m/\sqrt{3}$ $\tan\delta: \leq 0.004$ Providing capacitance of the sample(pF)	44 0.00300 413.6	
		Applied voltage(kV): U_m $\tan\delta: \leq 0.004$ Providing capacitance of the sample(pF)	72.5 0.00300 413.6	
17	Tightness test at the flange or other fixing device (Routine test)	Applied medium Applied pressure (MPa): 0.4 ± 0.01 Duration(min): 15 No leakage and damage	SF ₆ 0.4 15 No leakage and damage	Passed
18	Visual inspection and dimensions check (Routine test)	According to standard	See 4.18	Passed

Note: 1. All the tests were field tests;

2. Tested in Shandong Qixing High voltage Electric CO., Ltd laboratory.

Test Report

No: CTQC/ZJ-25.0095

Total 20 Page 6

1. Test object parameters

Highest voltage for equipment(kV): 72.5

Rated phase to earth voltage(kV): $72.5/\sqrt{3}$

Rated current(A): 1250

Rated frequency(Hz): 60

Altitude(m): ≤ 1000

Thermal class of insulation: E

Insulation type of bushing: RIP

Test tap(measured tap, $\tan\delta$): With

Rated voltage of voltage tap (Potential tap, capacitance tap)(kV): /

2. Sample condition description

Sample exterior construction and major dimensions(length, diameter) are in compliance with outline drawings.

Measured values: length 1890mm, outer diameter $\Phi 330$ mm.

Outline dimensions

Rating plate

PBT515

8QX.860.009G

Rating plate and outline drawings see testing report annex.

The form, performance data, specifications of sample rating plate are in compliance with drawing.

The surface of the sample has no collision and damage.

3. Standards

IEC60137: 2017, GB/T4109-2022 Insulated bushings for alternating voltage above 1000V

Technical contract

Test Report		No: CTQC/ZJ-25.0095 Total 20 Page 7		
4. Test items and conclusions				
4.1 Measurement of dielectric dissipation factor ($\tan \delta$) and capacitances at ambient temperature (Before type test) Test date: Feb. 10, 2025				
Humidity: 63.0%; Ambient temperature: 10.2°C; Atmospheric pressure: 102.0kPa				
Applied voltage(kV)	Dielectric dissipation factor($\tan \delta$)	Capacitance (pF)	Result	
10	0.00303	413.1	Passed	
44	0.00308	413.4		
72.5	0.00310	413.5		
Note: $\tan \delta(72.5\text{kV}) - \tan \delta(44\text{kV}) = 0.00002 < 0.001$ (Standard value), passed.				
4.2 Measurement of partial discharge quantity (Before type test) Test date: Feb. 10, 2025				
Humidity: 63.0%; Ambient temperature: 10.2°C; Atmospheric pressure: 102.0kPa				
Prestress voltage (kV)	Duration(s)	Measured voltage(kV)	Partial discharge level(pC)	Result
155	60	72.5	<4	Passed
		62.8	<4	
		44	<4	
Note: Background noise level was <4pC before and after test.				
4.3 Dry lightning impulse voltage withstand test (Type test) Test date: Feb. 10, 2025				
Test atmospheric conditions: Humidity: 63.0%; Ambient temperature: 10.2°C; Atmospheric pressure: 102.0kPa。				
Full wave withstand voltage: Positive 317.2(Corrected value)				
		Negative 357.5	15 positive and 15 negative polarity	
		Chopped wave withstand voltage: Negative 393.3	5 negative polarity	
Test sequence: One positive polarity reference voltage full wave impulse; Fifteen positive polarity rated voltage full wave impulse; One negative polarity reference voltage full wave impulse; One negative polarity rated voltage full wave impulse; Five negative polarity rated chopped wave impulse; Fourteen negative polarity rated voltage full wave impulses.				
Test oscillogram records: T1: Front time; T2: Time to half value; Upk: Peak voltage; Tc: Time to chopping; Oz: Factor of over crossing.				
Result: Passed.				

Test Report









No: CTQC/ZJ-25.0095

Total 20 Page 8

Tested terminal: To earth

Test polarity: Positive

CH1: Voltage records



Test Report









No : CTQC/ZJ-25.0095

Total 20 Page 9

Tested terminal: To earth

Test polarity: Positive

CH1: Voltage records










Test Report

No: CTQC/ZJ-25.0095

Total 20 Page 10

Tested terminal: To earth
 Test polarity: Negative
 CH1: Voltage records



Test Report









No : CTQC/ZJ-25.0095

Total 20 Page 11

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage records



Test Report







No: CTQC/ZJ-25.0095

Total 20 Page 12

Tested terminal: To earth

Test polarity: Negative

CH1: Voltage records



Test Report	No: CTQC/ZJ-25.0095 Total 20 Page 13
--------------------	---

4.4 Wet power-frequency voltage withstand test (Type test) Test date: Feb. 10, 2025
 Humidity: 63.0%; Ambient temperature: 10.2°C; Atmospheric pressure: 102.0kPa

Applied position	Applied voltage(kV)			Frequency (Hz)	Duration (s)	Result
	Standard value	Atmospheric corrected value	Applied value			
Terminal-earth	140	140.8	140.8	60	60	Passed

Note: The conductivity of collected water is 100.5μS/cm at 20°C.
 Average precipitation rate: Vertical component 1.4mm/min, horizontal component 1.2mm/min.

4.5 Long-duration power-frequency voltage withstand test (ACLD) (Type test) Test date: Feb. 16, 2025
 Humidity: 52.0%; Ambient temperature: 10.3°C; Atmospheric pressure: 102.3kPa

Applied voltage		Duration(min)	Partial discharge level(pC)
Multiple	Phase-earth(kV)		
$1.1U_m/\sqrt{3}$	46.1	5	<4
$U_2=1.5U_m/\sqrt{3}$	62.8	5	<4
$U_1=U_m$	72.5	1	/
$U_2=1.5U_m/\sqrt{3}$	62.8	5	<4
		10	<4
		15	<4
		20	<4
		25	<4
		30	<4
		35	<4
		40	<4
		45	<4
		50	<4
55	<4		
60	<4		
$1.1U_m/\sqrt{3}$	46.1	5	<4

Note: $U_m=72.5kV$; Background level is <4pC before and after test.
 Result: Passed.

Test Report

No: CTQC/ZJ-25. 0095

Total 20 Page 14

4.6 Temperature-rise test (Type test)

Test date: Feb. 13, 2025


Specified current was 1250A, injected current was 1250A during test, the test duration was 6h, stability duration was 1h.

Temperature-rise calculated value

No.	Measurement position	Temperature (°C)	Temperature rise(K)	Oil temperature (°C)	Ambient temperature (°C)	Result
1	Terminal in the air	57.3	47.2	70.4	10.1	Passed
2	Firmness of terminal in the air	56.4	46.4			
3	Top of internal conductive rod	55.8	45.7			
4	Mid of internal conductive rod	62.0	51.9			
5	Flange	49.9	39.8			
6	Tail of internal conductive rod	72.9	62.8			

The measurement position drawing is shown in page 15.

Schematic diagram of measured point of temperature rise



- 1. Terminal in the air 2. Firmness of terminal in the air 3. Top of internal conductive rod 4. Mid of internal conductive rod
- 5. Flange 6. Tail of internal conductive rod

Test Report		No: CTQC/ZJ-25.0095 Total 20 Page 16
<p>4.7 Verification of thermal short-time current withstand(Verify by the calculation) (Type test) Test date: Feb. 13, 2025</p> <p>The standard value of thermal short-time current of bushing $I_{th}=31.25\text{kA}$, duration $t_{th}=2\text{s}$. According to calculation final temperature of the conductor $\theta_f=146.3^\circ\text{C}$. If $\theta_f \leq 180^\circ\text{C}$, it was considered that the bushing could withstand the standard value I_{th} of thermal short-time current.</p> <p style="text-align: center;">Sample parameters</p>		
Conductor material of sample	Copper	
Conductor resistivity $\rho(\mu\Omega \cdot \text{cm})$	1.75	
Total cross section area $S_t(\text{cm}^2)$	11.3354	
Measured temperature rise of the bushing (K)	90	
Rated current $I_r(\text{A})$	1250	
Standard value of rated thermal short-time current $I_{th}(\text{kA})$	31.25	
Rated duration $t_{th}(\text{s})$	2	
$\theta_0(^\circ\text{C})$	130	
Current penetration depth $d(\text{cm})$	0.942	
Diameter of the conductor $D(\text{cm})$	3.8	
$\alpha[(\text{K/s})/(\text{kA}/\text{cm}^2)^2]$	0.8	
Equivalent cross section area considering the skin effect $S_e(\text{cm}^2)$	8.4536	
<p>Verify by the calculation:</p> $\theta_f = \theta_0 + \alpha \frac{I_{th}^2}{S_t \times S_e} \times t_{th} = 146.3^\circ\text{C}$		
<p>Result: Passed.</p>		

Test Report						No: CTQC/ZJ-25.0095 Total 20 Page 17
4.8 Cantilever load withstand test (Type test)						Test date: Feb. 16, 2025
Load direction	Applied position	Standard value		Applied value		Result
		Load(N)	Duration(s)	Load(N)	Duration(s)	
Vertical	Terminal	4000	60	4028	60	No damage, distortion, passed
4.9 Visual inspection and dimensions check (Type test)						Test date: Feb. 16, 2025
It has smooth surface, no cracks. Dimensional check is accordance with the drawing requirement.						
Drawing values (mm): 1880±20 725±5 700±10 Φ330 100						
Measured values (mm): 1890 725 705 Φ330 100						
Arcing distance (mm): 855 Creepage(mm): 2725						
Result: Passed.						
4.10 Measurement of partial discharge quantity (After type test)						Test date: Feb. 17, 2025
Humidity: 58.0%; Ambient temperature: 10.4°C; Atmospheric pressure: 102.8kPa						
Prestress voltage (kV)	Duration(s)	Measured voltage(kV)	Partial discharge level(pC)	Result		
155	60	72.5	<4	Passed		
		62.8	<4			
		44	<4			
Note: Background level is <2pC before and after test.						
4.11 Measurement of dielectric dissipation factor (tanδ) and capacitances at ambient temperature (After type test)						Test date: Feb. 17, 2025
Humidity: 58.0%; Ambient temperature: 10.4°C; Atmospheric pressure: 102.8kPa						
Applied voltage (kV)	Dielectric dissipation factor (tanδ)	Capacitance(pF)	Result			
10	0.00300	413.3	Passed			
44	0.00301	413.5				
72.5	0.00301	413.5				
Note: tanδ(72.5kV)- tanδ (4kV) = 0.00002 ≤ 0.001 (Standard value), passed.						

Test Report				No: CTQC/ZJ-25.0095 Total 20 Page 18	
4.12 Tests of tap insulation (Routine test)				Test date: Feb. 17, 2025	
Power-frequency voltage withstand test					
Humidity: 58.0%; Ambient temperature: 10.4°C; Atmospheric pressure: 102.8kPa					
Applied position	Applied voltage(kV)	Frequency(Hz)	Duration(s)	Result	
Tap—earth	3	60	60	Passed	
Measurement of dielectric dissipation factor (tanδ) and capacitances					
Humidity: 58.0%; Ambient temperature: 10.4°C; Atmospheric pressure: 102.8kPa					
Applied voltage(kV)	Dielectric dissipation factor(tanδ)	Capacitance(pF)	Result		
3	0.00502	194.0	Passed		
4.13 Dry lightning impulse voltage withstand test (Routine test)				Test date: Feb. 17, 2025	
Test atmospheric conditions					
Humidity: 58.0%; Ambient temperature: 10.4°C; Atmospheric pressure: 102.8kPa					
Full wave rated withstand voltage: negative polarity:341.3kV;				3 negative polarity	
Chopped wave rated withstand voltage: negative polarity:373.8kV;				2 negative polarity	
Test sequence					
One negative reference full wave impulse;					
One negative rated full wave impulses;					
Two negative rated chopped wave impulses;					
Two negative rated full wave impulses.					
Test records:					
T1: Front time; T2: Time to half value; Upk: Peak voltage;					
Tc: Time to chopping; Qz: Factor of over crossing.					
Result: Passed.					

Test Report







No : CTQC/ZJ-25. 0095

Total 20 Page 19

Tested terminal: To earth

Test polarity: Negative

CH2: Voltage wave



Test Report				No: CTQC/ZJ-25.0095 Total 20 Page 20		
4.14 Dry power-frequency voltage withstand test (Routine test)				Test date: Feb. 17, 2025		
Humidity: 58.0%; Ambient temperature: 10.4°C; Atmospheric pressure: 102.8kPa						
Position	Applied voltage(kV)			Frequency (Hz)	Duration (s)	Result
	Standard value	Atmospheric corrected value	Applied value			
Terminal—earth	155	/	155	60	60	Passed
4.15 Measurement of partial discharge quantity (Routine test)				Test date: Feb. 17, 2025		
Humidity: 58.0%; Ambient temperature: 10.4°C; Atmospheric pressure: 102.8kPa						
Prestress voltage (kV)	Duration(s)	Measured voltage(kV)	Partial discharge level(pC)	Result		
155	60	72.5	<4	Passed		
		62.8	<4			
		44	<4			
Note: Background level is <2pC before and after test.						
4.16 Measurement of dielectric dissipation factor ($\tan \delta$) and capacitances at ambient temperature (Routine test)				Test date: Feb. 17, 2025		
Humidity: 58.0%; Ambient temperature: 10.4°C; Atmospheric pressure: 102.8kPa						
Applied voltage (kV)	Dielectric dissipation factor ($\tan \delta$)	Capacitance(pF)	Result			
10	0.00299	413.5	Passed			
44	0.00300	413.6				
72.5	0.00300	413.6				
Note: $\tan \delta(72.5\text{kV}) - \tan \delta(44\text{kV}) = 0.00000 \leq 0.001$ (Standard value), Passed.						
4.17 Tightness test at the flange or other fixing device (Routine test)				Test date: Feb. 17, 2025		
Ambient temperature: 10.4°C						
Applied medium	Applied pressure(MPa)	Duration(h)	Residual pressure(MPa)	Result		
SF ₆ gas	0.4	15	0.4	No leakage or damage, passed		
4.18 Visual inspection and dimensions check (Routine test)				Test date: Feb. 17, 2025		
It has smooth surface, no cracks. Dimensional check is accordance with the drawing requirement.						
Dimensional inspection see 4.9.						
Result: Passed.						

RATING PLATE AND OUTLINE PHOTOS


Rating plate:

胶浸纸电容式变压器套管 Resin impregnated paper capacitive transformer bushing			
型号 Type	QXFBRPWD-L-72.5/1250-4	爬电距离 Creepage Dis.	2248 mm
品号 Kat. NO.	PBT515	重量 Weight	50 kg
出厂编号 Serial NO.	2502PB003	出厂日期 Date	2025.2.1
额定电压 Rated Voltage	72.5 kV	电容量 Capacitance	413.4 pF
额定电流 Rated Current	1250 A	介质损耗因数 Dielectric Dissipation Factor	0.308%
山东七星高压电气有限公司 Shandong Qixing High Voltage Electric Co., Ltd.			

Outline:







BUSHING DRAWINGS



借 (用) 用
件 登 记


旧图总号							产品型号				
新图总号							铭牌nameplate	图样标记		重量	比例
签字										0.030	1:1
日期	标记	数量	分区	更改文件号	签字	日期				共 张	第 张
档案员	日期	校核	会签		批准	日期		316L		Shandong Qixing High Voltage Electric Co., Ltd. 山东七星高压电气有限公司	
		设计 张学明		2025.2.1	标准						
		校核 石季刚		2025.2.1	审定						
					批准 曹明波	2025.2.1					



Technical parameters

1. Rated voltage: 72.5kV
2. Rated current: 1250A
3. 1min power frequency withstand voltage: 155kV
4. Lightning impulse withstand voltage: 325kV
5. Dielectric loss tangent: $\leq 0.4\%$
6. PD: Um measured ≤ 10
7. Bending load: 4000N
8. Creepage distance: 2248mm
9. Operating ambient temperature: $+65^{\circ}\text{C} \sim -60^{\circ}\text{C}$

设计		张孝明		2025.2.1		标准化		签名		年、月、日		QXFBRWD-1-72.5/1250-4		Shandong Qixing High Voltage Electric Co., LTD	
审核		石孝刚		2025.2.1		批准		曹明波		2025.2.1		共 张 第 张		Product number: PBT515	
工艺												阶段标记		Weight	
												比例		1:10	
														Printed on special paper capacitor transformer bushing	



CHPTL

中国大容量试验联盟（简称 CHPTL）是中国同类试验机构的唯一协作组织，隶属于中国电工技术学会。其主要目标是规范国家标准、行业标准及 IEC 标准在电力设备(交流 1000V 以上，直流 1200V 以上)型式试验中的协调应用。

China High Power Testing liaison (CHPTL) is the only organization in China which is formed to promote and coordinate the application of IEC/GB standard as well as industry standards in power electrical equipment type test (AC above 1000V, DC above 1200V). CHPTL is under the leadership and management of China Electro-technical Society.

CHPTL 成员单位如下：

The members of CHPTL are as follows:

西安高压电器研究院有限责任公司(XIHARI)

Xi'an High Voltage Apparatus Research Institute Co., Ltd. (XIHARI)

中国电力科学研究院(CEPRI)

China Electrical Power Research Institute (CEPRI)

辽宁高压电器产品质量检测有限公司(AQTC)

Liaoning High Voltage Apparatus Quality Test Co., Ltd. (AQTC)

沈阳变压器研究院有限公司变压器实验室(STRI)

Shenyang Transformer Institute Co., Ltd Transformer Laboratory (STRI)

上海电气输配电试验中心有限公司(SETC)

Shanghai Electric Power Transmission & Distribution Testing Center Co., Ltd. (SETC)

电力工业无功补偿成套装置质量检验测试中心(PRCIQTC)

Power Industry Reactive Compensation Equipment Quality Inspection & Test Center(PRCIQTC)

CHPTL 作为一个协作组织，本身并不出具型式试验报告。每一个 CHPTL 成员对其出具的型式试验报告的有效性和内容负责。

CHPTL as a collaboration does not itself issue test reports. Each CHPTL member issuing a test report is responsible for the validity and contents of